



P. O. Box 5666 Brandon MS 39047
Ph: (601) 914-4853 Fax: (601) 608-7866
EMAIL: ashish@mishraarch.com
WEB: www.mishraarch.com

S. K. International, Inc.
130 Main Street
Huntsville, AL 35811
Phone: (256) 852-3098
Fax: (256) 851-0686
Email: skint97@aol.com

William Council Tuberville
3080 Stage Post Drive, Suite 107
Memphis, TN 38116
Phone: (931) 676-3266

MECHANICAL:
Powell and Associates
886 Joe Dr
Collierville TN 38017-1415
Phone: (662) 890-4220
Fax: (662) 890-4224
Email: ROB@RHPOWELL.com

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. ©2008 MISHRA ARCHITECTURE PLLC



BAPS, INC.

YOGI YOUTH
CENTER

Greenway Drive
Jackson, MS 39206

Drawing Title

Electrical Site Plan

Scale: 1" = 30'-0"

Construction Documents

Project No.	07-051	Sheet No.
Prepared by	SMJ	E 100
Checked by	SMJ	
Date	Feb. 27, 2009	

CONSTRUCTION

GENERAL NOTES:

- 1) ALL WORK SHALL CONFORM TO ALL LOCAL, STATE AND FEDERAL CODES INCLUDING THE LATEST EDITION OF THE NATIONAL ELECTRIC CODE AND ADA GUIDELINES.
 - 2) ELECTRICAL CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING AND PROVIDING ALL NECESSARY LICENSES, PERMITS & INSPECTIONS AS WELL AS ANY OTHER NECESSARY FEES REGARDING THE ELECTRICAL INSTALLATION.
 - 3) VERIFY EXACT LOCATION OF ALL LIGHTING FIXTURES WITH THE ARCHITECT.
 - 4) VERIFY ALL NECESSARY POWER COMPANY REQUIREMENTS FOR METERING, OF CABINETS, PRIMARY SERVICE CONDUITS AND ANY METERING CANS, SOCKETS, AND CONDUITS.
 - 5) ALL HOME RUNS ON THIS SHEET SHALL BE A MINIMUM OF 1/2 THIN / THIN COPPER N A MINIMUM OF 3/4" CONDUIT. THE BALANCE OF THE CIRCUIT MAY BE REDUCED TO #10 THIN / THIN COPPER.
 - 6) PAID MOUNTED TRANSFORMER AT LOCAL POWER COMPANY - PAID AS DIRECTED BY LOCAL POWER COMPANY. PROVIDE PRIMARY SERVICE ENTRANCE CONDUITS & METERING CONDUITS & EQUIP. AS REQ'D BY LOCAL POWER CO.
 - 7) CONNECT P.V. VALVES TO FIRE ALARM SYSTEM. VERIFY LOCATION OF P.V. VALVES WITH SPRINKLER CONTRACTOR.
- UNDERGROUND SECONDARY ELECTRIC SERVICE ENTRANCE - 120/208V, 3-PHASE 4-WIRE.

