



CIVIL:
David Lane Beaird & Associates, Inc.
105 Commercial Parkway
West Monroe, LA 71294
Phone: (318) 388-3227
Email:fgadberry@dlbengineering.com

ELECTRICAL:
Ritter Engineering
1043 Arroyo Vista Lane
Matthew, NC 28014
Phone: (704) 516-0385
Fax: (704) 644-1464
Email: shane@rittereng.com

MECHANICAL:
Shultz Engineering Group, P.C.
212 North McDowell St., Suite 204
Charlotte, NC 28204
Phone: (704) 334-7363
Fax: (704) 347-0093
Email: don@shultzeg.com

[illegible]

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. ©2013 MISHRA ARCHITECTURE PLLC



KEY PLAN

Southern Hospitality
Services

Hampton Inn and Suites

5400 I-20 & Frontage Rd.
Monroe, LA 71201

Drawing Title

Sections

Phase
Construction Documents

Project No.	12-111	Sheet No.	A402
Prepared by	Author		
Checked by	Checker		
Date	Sept. 16, 2013		

Released for
PERMIT ONLY



FACE BRICK WITH 7/8" WIDE 29 GA. GALV. METAL TIES AT 32" O.C.
HORIZONTAL 16" O.C. VERTICAL W/ 1" AIR GAP 8" CMU BLOCK W/
WATERPROOFING 1" SCORED RIGID INSULATION. FURRYING
CANNELS W/ 5/8" GYP BD. ON INSIDE



-5/8" GYPSUM ON 6" WOOD STUDS @ 16" O.C. W/ UNFACED R-13 BATT INSULATION
-5/8" PLYWOOD SHEATHING
-2" DRAINABLE EIFS

- 60 MIL MECHANICALLY FASTENED TPO (THERMOPLASTIC OLEFIN) WHITE ROOFING MEMBRANE
- 3" MINIMUM RIGID INSULATION ON ROOF DECK.
- 5/8" GYP. BD. ON 2 1/2" FURRING CHANNELS @ 24" O.C. ON CEILING SIDE-SEE STRUCTURAL DRAWINGS FOR DETAILS

- PREFINISHED METAL COPING ON TREATED BLOCKING.
- ROOF MEMBRANE ALONG INSIDE FACE, UP AND OVER TOP OF PARAPET WALL
- PLYWOOD (FIRE TREATED) NAILER PANEL AT INSIDE FACE OF WALL-SEE DETAIL

3/4" GYPCRETE ON SEALANT OVER 23/32" STRUCTURAL PANELS ON 16"
WOOD TRUSSES @ 24" O.C.
5/8" F.C. GYP. BD. ON #26 MSG. RESILIENT CHANNELS @ 16" O.C.

ALL ACOUSTICAL CEILING TILE TO BE INSTALLED BELOW THE ONE-HOUR RATED FLOOR/CEILING ASSEMBLY WITHOUT COMPROMISING ON THE ASSEMBLY RATING. ALL PENETRATIONS TO BE FIRE-CAULKED AS PER UL STANDARDS TO PROVIDE ONE-HOURS FLOOR/CEILING ASSEMBLY ON ALL FLOORS.



NOTE:
ALL OPENINGS CUT INTO RATED FLOOR AND WALL
CONSTRUCTION SHALL BE SEALED WITH
FIRESTOPPING WITH RATING TO MATCH FLOOR AND
WALL RATING. SEALANTS SHALL BE BY
SUBCONTRACTOR CREATING OPENINGS.
FIRESTOPPING NOT REQUIRED AT FLOOR
PENETRATIONS WITH RATED SHAFT WALL
CONSTRUCTION.



TO BE USED ON ALL ELECTRICAL,
PHONE, AND TV BOXES. ELECTRICAL
CONTRACTOR RESPONSIBLE FOR
ALL ELECTRICAL BOXES AND PADS
AS IT RELATED TO THEIR CONTRACT.

DO NOT MOUNT ELECTRICAL BOXES
DIRECTLY ON STUDS.



4/14/2014 3:18:30 PM