


U.L. SYSTEM NO. FC2030
PLASTIC PIPE THROUGH 1-HR. WOOD FLOOR/FIRE RATED
CHASE WALL ASSEMBLY




- U.L. CLASSIFIED L500 SERIES FIRE-RATED WOOD FLOOR ASSEMBLY.
- LUMBER OR PLYWOOD SUBFLOOR WITH FINISH FLOOR OF LUMBER, PLYWOOD, OR FLOOR TOPPING MIXTURE.
- PENETRATING ITEM TO BE ONE OF THE FOLLOWING (SEE NOTE NO. 2):
A. MAXIMUM 3" DIAMETER PVC PIPE (CELLULAR AND SOLID CORE).
B. MAXIMUM 3" DIAMETER ABS PIPE (CELLULAR AND SOLID CORE).
C. MAXIMUM 3" DIAMETER FRPP PIPE.
D. MAXIMUM 3" DIAMETER CPVC PIPE.
- FILL ANNULAR SPACE BETWEEN THE PIPE AND FLOORING AND BETWEEN PIPE AND TOP PLATE TO THE MAXIMUM EXTENT POSSIBLE USING HILTI FS-ONE FIRESTOP SEALANT.
- TOP PLATE.
- GYPSUM WALL ASSEMBLY (1-HR. FIRE-RATED)
- HILTI CP 642 FIRESTOP COLLAR (SEE TABLE BELOW)

PIPE DIAMETER	PRODUCT DESCRIPTION	NO. OF MOUNTING TABS	MAX. HOLE SIZE	T RATING
1 1/2"	CP 642 50/1.5"	2	2 3/8"	1-HR.
2"	CP 642 63/2"	2	2 5/8"	1-HR.
3"	CP 642 90/3"	3	4"	1-HR.

NOTES: 1. ANNULAR SPACE = MINIMUM 1/8", MAXIMUM 3/8".
2. CLOSED OR VENTED PIPING SYSTEM (ABS, PVC, FRPP = SCHEDULE 40, CPVC = SDR 17).

4 FIRE STOPPING DETAIL
NO SCALE

U.L. SYSTEM NO. FC2025
PLASTIC PIPE THROUGH 1-HR. OR 2-HR. WOOD FLOOR
OR FIRE-RATED CHASE WALL ASSEMBLY



- WOOD FLOOR ASSEMBLY (U.L. CLASSIFIED L500 SERIES)(1-HR. FIRE-RATED FLOOR SHOWN).
- LUMBER OR PLYWOOD SUBFLOOR WITH FINISH FLOOR OF LUMBER, PLYWOOD, OR FLOOR TOPPING MIXTURE.
- PENETRATING ITEM TO BE ONE OF THE FOLLOWING:
A. MAXIMUM 4" DIAMETER PVC PIPE (CELLULAR AND SOLID CORE).
B. MAXIMUM 4" DIAMETER CPVC PIPE.
C. MAXIMUM 4" DIAMETER ABS PIPE (CELLULAR AND SOLID CORE).
D. MAXIMUM 4" DIAMETER FRPP PIPE.
- HILTI CP 642 FIRESTOP COLLAR (SEE TABLE BELOW)
- GYPSUM WALL ASSEMBLY (1-HR. AND 2-HR. FIRE-RATING)(1-HR. SHOWN).
- TOP PLATE.
- SEE NOTE NO. 1 BELOW
- WOOD SCREWS WITH WASHERS TO FASTEN EACH MOUNTING TAB.


PIPE DIAMETER	PRODUCT DESCRIPTION	NO. OF MOUNTING TABS	MAX. HOLE SIZE	1-HR. FLOOR	2-HR. FLOOR
1 1/2"	CP 642 50/1.5"	2	2 3/8"	1	2
2"	CP 642 63/2"	2	2 5/8"	0	1 1/2
3"	CP 642 90/3"	3	4"	0	1 1/2
4"	CP 642 110/4"	4	5"	0	1 1/2

NOTES: 1. PROVIDE 1/2" DEPTH HILTI FS-ONE FIRESTOP SEALANT IN ANNULAR SPACE AROUND PIPE.
2. ANNULAR SPACE = MINIMUM 0", MAXIMUM 1/4".
3. CLOSED OR VENTED PIPING SYSTEM (ABS, PVC, AND FRPP = SCHEDULE 40, CPVC PIPE = SDR 17).

3 FIRE STOPPING DETAIL
NO SCALE

System No. W-L-2078

- F Ratings— 1 and 2 Hr (See Item 1)
T Ratings— 0, 1 and 2 Hr (See Items 2 and 3)
L Rating At Ambient— 3 CFM/sq ft
L Rating At 400 F— Less Than 1 CFM/sq ft




- Wall Assembly— The fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner specified in the individual U300, U400 or V400 Series Wall and Partition Designs in the UL fire Resistance Directory and shall include the construction features noted below:
A. Studs— Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nom 2 by 4 in. lumber spaced max 16 in. OC. Steel studs to be min 2-1/2 in. wide and spaced max 24 in. OC.
B. Gypsum Board*— Nom 5/8 in. thick gypsum board, as specified in the individual Wall and Partition Design. Max diam of opening is 11-1/2 in.
The hourly F Rating of the firestop system is equal to the hourly fire rating of the wall assembly in which it is installed.
- Through-Penetrants— One nonmetallic pipe, conduit or tubing to be installed within the firestop system. The annular space between pipe and periphery of opening shall be min 0 in. (point contact) to max 1/2 in. Pipe or conduit to be rigidly supported on both sides of the wall assembly. The following types and sizes of nonmetallic pipes may be used:
A. Polyvinyl Chloride (PVC) Pipe— Nom 10 in. diam (or smaller) Schedule 40 solid-core or cellular core PVC pipe for use in closed (process or supply) or vented (drain, waste or vent) piping system.
B. Chlorinated Polyvinyl Chloride (CPVC) Pipe— Nom 10 in. diam (or smaller) SDR13.5 CPVC pipe for use in closed (process or supply) piping systems.
C. Acrylonitrile Butadiene Styrene (ABS) Pipe— Nom 6 in. diam (or smaller) Schedule 40 solid-core or cellular core ABS pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems.
D. Flame Retardant Polypropylene (FRPP) Pipe— Nom 6 in. diam (or smaller) Schedule 40 FRPP pipe for use in closed (process or supply) or vented (drain, waste or vent) piping system.
E. Polyvinylidene Fluoride (PVDF) Pipe— Nom 4 in. diam (or smaller) PVDF pipe for use in closed (process or supply) or vented (drain, waste or vent) piping system.
When max 6 in. diam pipe is used, T Rating is equal to the hourly fire rating of the wall. When nom 8 in. or 10 in. diam pipe is used, T Rating is 0 hr.
- Firestop Device*— Firestop Collar— Firestop collar shall be installed in accordance with the accompanying installation instructions. Collar to be installed and latched around the pipe and secured to both sides of the wall using the anchor hooks provided with the collar. (Minimum two anchor hooks for 1-1/2 and 2 in. diam pipes, three anchor hooks for 3 and 4 in. diam pipes, four anchor hooks for 6 in. diam pipes, ten anchor hooks for 8 in. diam pipes and twelve anchor hooks for 10 in. diam pipes) . The anchor hooks are to be secured to the surface of wall with 3/16 in. diam by 2-1/2 in. long steel toggle bolts along with washers. As an alternate for pipe sizes of nom 4 in. diam or less, min No. 10 by 1-1/2 in. long drywall or laminate screws with min 3/4 in. steel washers may be used. When the drywall or laminate screw is used, T Rating shall not exceed 1 hr.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC.— CP 643 50/1.5"N, CP 643 63/2"N, CP 643 90/3"N, CP 643 110/4"N, CP 643 160/6"N, CP 644 200/8" and CP 644 250/10" Firestop Collars
4. Fill, Void or Cavity Material*— Sealant - (Not Shown) — Min 1/2 in. thickness of sealant applied within the annular space for nom 8 in. and 10 in. diam pipes, flush with each side of wall. Sealant in annular space is optional for max 6 in. diam pipes. A min 1/4 in. thickness of sealant is required within the annular space, flush with each side of wall, to attain the L Ratings for max 6 in. diam pipes.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-One Sealant
*Bearing the UL Classification Mark



2 FIRE STOPPING DETAIL
NO SCALE

System No. W-L-5029

- F Ratings— 1 and 2 Hr (See Item 1)
T Ratings— 1/2, 3/4, 1, 1-1/2 and 1-3/4 Hr (See Item 3)
L Rating At Ambient— 4 CFM/Sq Ft
L Rating At 400 F— Less Than 1 CFM/Sq Ft




- Wall Assembly— The 1 or 2 hr fire-rated gypsum board/stud wall assembly shall be constructed of the materials and in the manner specified in the individual U300 or U400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:
A. Studs— Wall framing may consist of either wood studs or steel channel studs. Wood studs to consist of nom 2 by 4 in. lumber spaced 16 in. OC. Steel studs to be min 2-1/2 in. wide and spaced max 24 in. OC.
B. Gypsum Board*— 5/8 in. thick, 4 ft wide, with square or tapered edges. The gypsum board type, thickness, number of layers, fastener type and sheet orientation shall be as specified in the individual Wall and Partition Design. Max diam of opening is 18-5/8 in.
The hourly F Rating of the firestop system is equal to the hourly fire rating of the wall assembly in which it is installed.
- Through Penetrants— One metallic pipe or tubing to be centered within the firestop system. Pipe or tubing to be rigidly supported on both sides of wall assembly. The following types and sizes of metallic pipes or tubing may be used:
A. Steel Pipe— Nom 12 in. diam (or smaller) Schedule 10 (or heavier) steel pipe.
B. Iron Pipe— Nom 12 in. diam (or smaller) cast or ductile iron pipe.
C. Copper Tubing— Nom 6 in. diam (or smaller) Type L (or heavier) copper tubing.
D. Copper Pipe— Nom 6 in. diam (or smaller) Regular (or heavier) copper pipe.
3. Pipe Covering*— Nom 1, 1-1/2 or 2 in. thick hollow cylindrical heavy density (min 3.5 pcf) glass fiber units jacketed on the outside with an all service jacket. Longitudinal joints sealed with metal fasteners or factory-applied self-sealing lap tape. Transverse joints secured with metal fasteners or with butt tape supplied with the product.
See Pipe and Equipment Covering— Materials (BRGU) category in the Building Material Directory for the names of manufacturers. Any pipe covering material meeting the above specifications and bearing the UL Classification Marking with a Flame Spread Index of 25 or less and a Smoke Developed Index of 50 or less may be used.
The hourly T Rating of the firestop system is dependent on the hourly fire rating of the wall assembly in which it is installed, the size and type of through penetrant and the pipe covering thickness, as shown in the table below.

Wall Assembly Rating Hr	Through Penetrant		Pipe Covering Thkns In.	Annular Space		T Rating Hr
	Type +	Max Diam In.		Min In.	Max In.	
1	A	4	1	0	1-1/2	1/2
1	B or C	2	1 or 1-1/2	0	1-1/2	1/2
1	A	4	1-1/2	0	1-1/2	1
1	A	12	2	0	1-7/8	3/4
1	B or C	6	2	0	1-7/8	1
2	A	4	1	0	1-1/2	1
2	B or C	4	1 or 1-1/2	0	1-1/2	1
2	B or C	6	2	0	1-7/8	1
2	A	4	1-1/2	0	1-1/2	1-3/4
2	A	12	2	0	1-7/8	1-1/2
2	B or C	6	2	0	1-7/8	1

- *Indicates penetrant type as itemized in Item 2.
3A. Pipe Covering* — (Not Shown) — As an alternate to Item 3, max 2 in. thick cyindrical calcium silicate (min 14 pcf) units sized to the outside diam of the pipe or tube may be used. Pipe insulation secured with stainless steel bands or min 8 AWG stainless steel wire spaced max 12 in. OC. When the alternate pipe covering is used, the T Rating shall be determined from the table above.
See Pipe and Equipment Covering— Materials (BRGU) category in the Building Materials Directory for names of manufacturers. Any pipe covering material meeting the above specifications and bearing the UL Classification Marking with a Flame Spread Index of 25 or less and a Smoke Developed Index of 50 or less may be used.
4. Fill, Void or Cavity Material*— Sealant— Min 5/8 in. thickness of fill material applied within the annulus, flush with both surfaces of wall. At the point contact location between pipe covering and gypsum board, a min 1/2 in. diam bead of fill material shall be applied at the pipe covering/gypsum board interface on both surfaces of wall.
HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-One Sealant
*Bearing the UL Classification Mark



1 FIRE STOPPING DETAIL
NO SCALE



6800 S Creek Rd, Charlotte, NC 28277
Ph:(704) 625-6554 Fax:(704) 919-5822
EMAIL:ashish@mishraarch.com
WEB: www.mishraarch.com




SHULTZ
ENGINEERING
GROUP, PC

212 N. McDowell St
Suite 204
Charlotte, NC 28204
(P) 704.334.7363
(F) 704.347.0093
www.shultzeng.com
SEC - 13-039

REVISIONS		
No.	Date	Description

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated.* 2011 MISHRA ARCHITECTURE PLLC



KEY PLAN

Southern Hospitality
Services

Hampton Inn and
Suites

5400 I-20 & Frontage Rd.
Monroe, LA 71201

Drawing Title

Details - Fire Protection

Phase

FOR CONSTRUCTION

Project No. 12-111

Prepared by JCF

Checked by WGA

Date September 16, 2013

Sheet No.

FP002

Released for

Hampton Inn and Suites