


REVISIONS		
No.	Date	Description

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. © 2011 MISHRA ARCHITECTURE PLLC



KEY PLAN

Southern Hospitality  
Services

Hampton Inn and  
Suites

5400 I-20 & Frontage Rd.  
Monroe, LA 71201

Drawing Title  
Mechanical HVAC  
Details

Phase  
FOR CONSTRUCTION

Project No.	12-111	Sheet No.	M201
Prepared by	CDC		
Checked by	GWA		
Date	September 16, 2013		

Released for

Hampton Inn and Suites

NOTES:  
1. PROVIDE PIPE SUPPORTS AT 10'-0" ON CENTER.  
2. PROVIDE ADDITIONAL SUPPORTS AT EQUIPMENT TO PREVENT THE WEIGHT OF PIPING BEING PLACED ON THE EQUIPMENT.

1 EQUIPMENT SUPPORT DETAIL  
M201 NO SCALE

NOTES:  
1. PROVIDE EQUIPMENT CURB TO MATCH ROOF SLOPE.  
2. THIS DETAIL IS TYPICAL FOR ALL EXH. & O.A. INTAKE DUCTS

2 ROOF MOUNT FRESH AIR INTAKE  
M201 NO SCALE

1. CLOTHES DRYER  
2. RECESSED METAL BOX 18"x14"x5 1/2"  
3. 4" RIGID DRYER VENT  
4. DRYER FLEX HOSE  
5. WALL STUDS  
6. 2x4 BLOCKING

THIS DETAIL IS FOR THE DRYERS IN THE GUEST LANDRY

3 RECESSED METAL BOX/DRYER EXHAUST  
M201 NO SCALE

4 PIPE PORT DETAIL  
M201 NO SCALE

5 OUTDOOR UNIT PAD DETAIL  
M201 NO SCALE

MC SHALL PROVIDE FLASHING TYPE COMPATIBLE WITH ROOF STRUCTURE TYPE

6 DUCT PENETRATION THRU ROOF DETAIL  
M201 NO SCALE