


1 THIRD FLOOR PLAN - MECHANICAL
M302 SCALE: 1/8" = 1'-0"

SET EXHAUST FANS IN
GUEST ROOM
BATHROOMS TO RUN AT
25 CFM CONTINUOUSLY

REVISIONS		
No.	Date	Description

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. © 2011 MISHRA ARCHITECTURE PLLC



KEY PLAN

Southern Hospitality
Services

Hampton Inn and
Suites

5400 I-20 & Frontage Rd.
Monroe, LA 71201

Drawing Title
Mechanical HVAC
Third Floor Plan

Phase
FOR CONSTRUCTION

Project No.	12-111	Sheet No.	M302
Prepared by	CDC		
Checked by	GWA		
Date	September 16, 2013		
Released for			

Hampton Inn and Suites