*NOTE!

SEE 9/301 FOR THICKENED SLAB UNDER WASHER - COORDINATE W/ ARCH. AND PLUMBING DWGS.

NOTE!

PROVIDE #5 @ 24" O.C. VERTICAL AT ALL
CMU STAIR AND ELEVATOR WALLS — PROVIDE 8" DEEP CONT. BOND BEAM AT LANDING ELEVATIONS — GROUT ALL CELLS

4" CONCRETE \$LAB (3000 PSI) WITH 6x6-W1.4xW1.4

W.W.F. OR FIBERMESH 300 (SEE GEN. NOTES) - ON

VAPOR RETARDER ON 4" DRAINAGE FILL - LOCATE

W.W.F. IN UPPER THIRD OF SLAB — PROVIDE SLAB

1/S301) - F.F.E. 71.50' (0'-0")

CONSTRUCTION/CONTROL JOINT @ 10'-0" MAX. (SEE

5 S301

WF40___

GENERAL CONTRACTOR SHALL COORDINATE/VERIFY ALL DIMENSIONS WITH ARCHITECTURAL DRAWINGS

NOTE!

SEE 8/S301 AND ARCH/PLUMBING DWGS. FOR SUMP PUMP PIT

NOTE!

ALL EXTERIOR WALLS ARE SHEAR WALLS SW2. SW1 INDICATES INTERIOR SHEAR WALL. SEE SHEET S002 FOR SHEAR WALL SCHEDULE.

-D.7

NOTE!

S302

SEE SOILS REPORT FOR FOOTING BEARING ELEVATION INFORMATION - SOILS ENGINEER SHALL FIELD VERIFY TOP OF FOOTING ELEVATIONS - TYPICAL



6800 S Creek Rd, Charlotte, NC 28277 Ph:(704) 625-6554 Fax:(704) 919-5822 EMAIL:ashish@mishraarch.com WEB: www.mishraarch.com

CIVIL: James W Braswell and Associates 1005 North 4th Street Monroe, LA 71201 Phone:

Email:braswellassociates@yahoo.com

STRUCTURAL: WGPM, Inc.

Fax:

11220 Elm Lane, Suite 201 Charlotte, NC 28277 Phone: (704) 542-7199 Fax: (704) 542-7195 Email: lwright@wgpminc.com


ELECTRICAL: Ritter Engineering 1043 Arroyo Vista Lane Matthew, NC 28014 Phone: (704) 516-0385 Fax: (704) 644-1464

Email: shane@rittereng.com MECHANICAL:
Shultz Engineering Group, P.C. 212 North McDowell St., Suite 204 Charlotte, NC 28204 Phone: (704) 334-7363 Fax:(704) 347-0093

Email: don@shultzeg.com

REVISIONS					
No.	Date	Description			
1	11.01.13	Pool Equip.,			
		Ftgs & Rf Slope			
2	03.11.14	Canopy			


Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. ବ 2011 MISHRA ARCHITECTURE PLLC



KEY PLAN

Southern Hospitality Services

Hampton Inn and Suites





MASONRY WALLS - TYPICAL UNLESS NOTED


NOTE! 5400 I-20 & Frontage Rd. SHALL NOT BE USED | Monroe, LA 71201

| Foundation and #5 @ 24" VERTICAL ALL 8" CMU WALLS - SEE SHEET S302 - PROVIDE W1.7 (9 GA.) TRUSS TYPE Floor Slab Plan

HORIZONTAL JOINT REINFORCING @ 16" MAX. ALL Construction Documents







12-111 Prepared by AB/LW Checked by HLW Date September 16, 2013

WGPM, Inc. Wright + Gibson + Patton STRUCTURAL ENGINEERING 11220 Elm Lane, Suite 201 Charlotte, North Carolina 28277 704-542-7199 Fax: 704-542-7195 www.wgpminc.com JOB NUMBER: 57-13

OTHERWISE

1. ALL ELEVATIONS REFERENCED () FROM FINISH FLOOR ELEVATION 71.50' (0-0). 2. INTERIOR TOP OF FOOTING - T.O.F. (-1'-4") TYPICAL UNLESS NOTED OTHERWISE. 3. EXTERIOR TOP OF FOOTING - T.O.F. (-1'-4") TYPICAL UNLESS NOTED OTHERWISE.
4. CONTRACT DRAWINGS SHALL NOT BE USED FOR SHOP DRAWINGS. SEE SHEET S001 AND S002 FOR GENERAL NOTES, WALL STUDS AND WALL SHEATHING NOTES. 6. SEE SHEET S302 FOR COLUMN BASE PLATE AND ANCHOR ROD SCHEDULE. 7. ALL FOOTING STEPS 24" TYPICAL UNLESS NOTED OTHERWISE - SEE 2/S301. 8. SW1 INDICATES SHEAR WALL 1 - SEE SHEAR WALL SCHEDULE ON SHEET SO02 TYPICAL.

1 FOUNDATION AND FLOOR SLAB PLAN

FOOTING SCHEDULE (2000 PSE)

FOOTING	SCHEDULE	(2000 P3F)	
MARK	SIZE	THICK.	REINFORCING
F35 F45 F50 F50* F55* F60 F65	3'-6"x3'-6" 4'-6"x4'-6" 5'-0"x5'-0" 5'-0"x5'-0" 5'-6"x5'-6" 6'-0"x6'-0" 6'-6"x6'-6"	1'-0" 1'-0" 1'-6" 1'-8" 1'-0" 1'-6"	4 #4 x3'-0" EACH WAY 7 #4 x4'-0" EACH WAY 5 #5 x4'-6" EACH WAY 5 #5 x4'-6" E.W.T. & B. 6 #5 x5'-0" E.W.T. & B. 7 #5 x5'-6" EACH WAY 8 #5 x6'-0" EACH WAY 8 #5 x6'-0" E.W.T. & B.
F75	7'-6"×7'-6"	1'-2"	8 #6 x7'-0" FACH WAY

 $\frac{1-6}{6}$ $\frac{1-2}{6}$ 8 #6 x/'-0" EACH WAY SOILS LABORATORY SHALL VERIFY SOIL BEARING PRESSURE AT BOTTOM OF EACH FOOTING PRIOR TO PLACING CONCRETE. STRUCTURAL FILL SUPPORTING SLAB OR FOOTINGS SHALL BE PLACED IN MAXIMUM 8" LIFTS, WITH EACH 8" LIFT TESTED BY LABORATORY FOR COMPACTION LISTED IN GENERAL NOTES. E.W.T. & B. INDICATES EACH WAY TOP AND BOTTOM

	WALL FOOTING SCHEDULE 4,000 PSF SOIL BEARING							
MARK	WIDTH	THICKNESS	LONGITUDINAL REINF.	TRANSVERSE REINF.	COMMENTS			
WF30	3'-0"	1'-3"	3 #4 TOP	#3x2'-6" @ 24" O.C. TOP	SEE 11/S301			
			3 #5 BOTTOM	#4x2'-6" @ 24" O.C. BOTTOM	SEE 12/S301			
WF40	4'-0"	1'-4"	5 #4 TOP	#4x3'-6" @ 24" O.C. TOP	SEE 11/S301			
			5 #5 BOTTOM	#4x3'-6" @ 16" O.C. BOTTOM	SEE 12/S301			
WF55	5'-6"	1'-4"	6 #4 TOP	#4x5'-0" @ 24" O.C. TOP	SEE 6/S301			
			6 #6 BOTTOM	#5x5'-0" @ 16" O.C. BOTTOM	SEE 4 & 6/S302			