HEADER, SILL, AND JAMB SCHEDULE

H1 3 - 2x6 + PLYWOOD FILLER H2 3 - 2x8 + PLYWOOD FILLER H3 3 - 2x12 + PLYWOOD FILLER

S1 2 - 2x6 SILL

J1 2 - 2x6 JACK STUDS + 1 - 2x6 BYPASS STUDS J2 2 - 2x6 JACK STUDS + 2 - 2x6 BYPASS STUDS J3 2 - 2x6 JACK STUDS + 3 - 2x6 BYPASS STUDS J4 3 - 2x6 JACK STUDS + 1 - 2x6 BYPASS STUDS

1. ALL HEADERS ARE H1, ALL SILLS ARE S1 AND ALL JAMB STUDS ARE J1 UNLESS NOTED OTHERWISE.

2. PROVIDE DOUBLE JACK (CRIPPLE) STUDS UNDER EACH END OF ALL HEADERS AND DOUBLE BYPASS (KING) STUDS EACH SIDE OF JACK STUDS (U.N.O.) - SEE 8/S302.

PROVIDE #5 @ 24" O.C. VERTICAL — AT ALL CMU STAIR AND ELEVATOR

WALLS - PROVIDE 8" DEEP CONT.

- GROUT ALL CELLS SOLID

BOND BEAM AT LANDING ELEVATIONS

NOTE!

ALL EXTERIOR WALLS ARE SHEAR WALLS SW2. SW1 INDICATES INTERIOR SHEAR WALL. SEE SHEET S002 FOR SHEAR WALL SCHEDULE.

SEE SHEET S002 FOR WALL STUDS AND PLYWOOD/OSB WALL SHEATHING - TYPICAL

H1 - TYP. U.N.O. NOTE!

S402

INDICATES SIMPSON ANCHOR

ON SHEET S601 (22 REQ'D)

TIEDOWN SYSTEM - SEE DETAILS

NOTE!

OPEN

23/32" TONGUE AND GROOVE PLYWOOD/OSB SUBFLOOR WITH SPAN RATING OF 48/24 OR BETTER. ATTACH TO SUPPORTING MEMBERS USING 10GA. x 2" LONG SCREWS @ 6" O.C. EDGES AND @ 12" O.C.

INTERMEDIATE - GLUE TO ALL SUPPORTING MEMBERS. LAYOUT

ARCH. FOR GYPCRETE TOPPING.

(21)

FIN. FL. (+22'-8") - T.O.PLYWOOD - 3RD FL. FIN. FL. (+33'-4") - T.O.PLYWOOD - 4TH FL.

STAGGERED AND PERPENDICULAR TO SUPPORTING MEMBERS. SEE

10 S403

ALL INTERIOR HEADERS ARE HI AND JAMBS ARE JI U.N.O. ALL EXTERIOR HEADERS ARE H2 AND JAMBS ARE J2 U.N.O.

4 \$402

S401

5

S402

MECHANICAL DUCTWORK RUNS THROUGH TRUSSES - COORDINATE DIAGONALS W/ MECH. CONTR.

NOTE:

\$402

J2 J2 | J2

24" DEEP PREFABRICATED WOOD FLOOR TRUSSES @

TRUSSES AS REQUIRED - GENERAL CONTRACTOR TO COORDINATE ALL SHAFT OPENING LOCATIONS AND

24" O.C. MAX. - PROVIDE HEADER AND GIRDER

DIMENSIONS - TYP.

(12)

13

(14)

J2 J2 J2 J2

ALL TEMPORARY TRUSS BRACING REQUIRED FOR ERECTION, AS PER THE GUIDELINES SET FORTH BY THE TRUSS PLATE INSTITUTE PUBLICATION "HIB-91" SHALL BE PERMANENTLY ATTACHED AND REMAIN IN PLACE TO SERVE AS PERMANENT TRUSS BRACING UNLESS NOTED OTHERWISE. PROVIDE TRUSS BOTTOM CHORD BRACING AS REQUIRED.

TRUSSES SHALL BE DESIGNED FOR ALL

5 \$402

(S401)

AND PROVIDE ADDITIONAL TRUSSES IF REQ'D.



6800 S Creek Rd, Charlotte, NC 28277 Ph:(704) 625-6554 Fax:(704) 919-5822 EMAIL:ashish@mishraarch.com WEB: www.mishraarch.com

ADDITIONAL LOADS SHOWN ON FRAMING PLANS CIVIL: James W Braswell and Associates 1005 North 4th Street Monroe, LA 71201

Email:braswellassociates@yahoo.com

Phone:

11220 Elm Lane, Suite 201 Charlotte, NC 28277

Phone: (704) 542-7199 Fax: (704) 542-7195 Email: lwright@wgpminc.com ELECTRICAL:
Ritter Engineering

1043 Arroyo Vista Lane Matthew, NC 28014 Phone: (704) 516-0385 Fax: (704) 644-1464 Email: shane@rittereng.com

MECHANICAL:
Shultz Engineering Group, P.C.
212 North McDowell St., Suite 204 Charlotte, NC 28204 Phone: (704) 334-7363 Fax:(704) 347-0093 Email: don@shultzeg.com

REVISIONS No. Date Description 1 11.01.13 Pool Equip., Ftgs & Rf Slope

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. 2011 MISHRA ARCHITECTURE PLLC

KEY PLAN Southern Hospitality

Hampton Inn and Suites

Services

NOTE!
CONTRACT DRAWINGS SHALL NOT BE USED FOR SHOP DRAWINGS

(9)

#5 @ 24" VERTICAL ALL 8" CMU WALLS - SEE

MASONRY WALLS - TYPICAL UNLESS NOTED

5 \$402

H2 - TYP. U.N.O.

5400 I-20 & Frontage Rd. Monroe, LA 71201

Third and Fourth SHEET S302 - PROVIDE W1.7 (9 GA.) TRUSS TYPE
HOPIZONIAL JOINT PEINFORCING @ 16" MAY ALL
Plan

HORIZONTAL JOINT REINFORCING @ 16" MAX. ALL

Construction Documents

12-111 Prepared by AB/LW Checked by HLW

ate September 16, 2013

Wright + Gibson + Patton 11220 Elm Lane, Suite 201 Charlotte, North Carolina 28277 704-542-7199 Fax: 704-542-7195 www.wgpminc.com JOB NUMBER: 57-13

OTHERWISE

WGPM, Inc. STRUCTURAL ENGINEERING

MARCUS C. GIBSON License No.32774

NOTE! BB INDICATES 8" DEEP CONTINUOUS BOND BEAM W/ 2 #4 CONTINUOUS GROUT SOLID - 16BB INDICATES 16" DEEP CONTINUOUS

THIRD AND FOURTH FLOOR FRAMING PLAN

UNLESS NOTED OTHERWISE.

1. ALL ELEVATIONS REFERENCED FROM FINISH FLOOR ELEVATION 71.50' (0-0). 2. TRUSS BEARING - T.B. (+20'-7 1/4") THIRD FLOOR AND (+31'-3 1/4") FOURTH FLOOR - TYPICAL

2 S404

S402

15)

J1 - TYP. U.N.O.

W12x22 W/ HSS 6x4x5/16

ELEVATOR GUIDE RAIL -SEE 6/S403 FOR BEAM

BEARING DETAIL - TYP.

6 S402

H1 - TYP. U.N.O.

J2 – TYP. U.N.O.

5 \$403

8 \$401

H2 - TYP. U.N.O.

4. CONTRACT DRAWINGS SHALL NOT BE USED FOR SHOP DRAWINGS. SEE SHEET S001 AND S002 FOR GENERAL NOTES, WALL STUDS AND WALL SHEATHING NOTES.

6. LVL INDICATES MICRO=LAM LVL BY I-LEVEL OR EQUIVALENT.

BB INDICATES 8" DEEP BOND BEAM - SEE 5/S302. 8. SW1 INDICATES SHEAR WALL 1 - SEE SHEAR WALL SCHEDULE ON SHEET SO02 TYPICAL.

BOND BEAM W/ 2 #4 CONTNUOUS GROUT

SOLID - SEE SECTIONS