

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 225A, MLO	PANEL "HE" (THIRD FLR. A/C UNITS)	MOUNTING: SURFACE A/C: 10K REMARKS:
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
1 20 2 12 1/2 GUEST ROOM 501		2 20 2 12 1/2 GUEST ROOM 500
3 - - 12 1/2 GUEST ROOM 501		4 - - 12 1/2 GUEST ROOM 500
5 20 2 12 1/2 GUEST ROOM 503		6 20 2 12 1/2 GUEST ROOM 502
7 - - 12 1/2 GUEST ROOM 503		8 - - 12 1/2 GUEST ROOM 502
9 20 2 12 1/2 GUEST ROOM 505		10 20 2 12 1/2 GUEST ROOM 504
11 - - 12 1/2 GUEST ROOM 505		12 - - 12 1/2 GUEST ROOM 504
13 20 2 12 1/2 GUEST ROOM 507		14 20 2 12 1/2 GUEST ROOM 506
15 - - 12 1/2 GUEST ROOM 507		16 - - 12 1/2 GUEST ROOM 506
17 20 2 12 1/2 GUEST ROOM 509		18 20 2 12 1/2 GUEST ROOM 508
19 - - 12 1/2 GUEST ROOM 509		20 - - 12 1/2 GUEST ROOM 508
21 20 2 12 1/2 GUEST ROOM 513		22 20 2 12 1/2 GUEST ROOM 510
23 - - 12 1/2 GUEST ROOM 513		24 - - 12 1/2 GUEST ROOM 510
25 20 2 12 1/2 GUEST ROOM 515		26 20 2 12 1/2 GUEST ROOM 512
27 - - 12 1/2 GUEST ROOM 515		28 - - 12 1/2 GUEST ROOM 512
29 20 2 12 1/2 GUEST ROOM 517		30 20 2 12 1/2 GUEST ROOM 514
31 - - 12 1/2 GUEST ROOM 517		32 - - 12 1/2 GUEST ROOM 514
33 20 2 12 1/2 GUEST ROOM 519		34 20 2 12 1/2 GUEST ROOM 516
35 - - 12 1/2 GUEST ROOM 519		36 - - 12 1/2 GUEST ROOM 516
37 20 2 12 1/2 GUEST ROOM 521		38 20 2 12 1/2 GUEST ROOM 518
39 - - 12 1/2 GUEST ROOM 521		40 - - 12 1/2 GUEST ROOM 518
41 20 1 12 1/2 LINEN/STOR. LTS		42 20 1 12 1/2 LINEN/STOR. LTS
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		RE-E-10.0 FOR FEEDER CALCU.

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 100A, MLO	PANEL "LD" (FOURTH FLR. GUEST RMS.)	MOUNTING: SURFACE A/C: 10K REMARKS: SECTION 1 SUB FEED LUGS
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
1 20 1 12 1/2 GUEST ROOM 401		2 20 1 12 1/2 GUEST ROOM 400
3 20 1 12 1/2 GUEST ROOM 401		4 20 1 12 1/2 GUEST ROOM 400
5 20 1 12 1/2 GUEST ROOM 401		6 20 1 12 1/2 GUEST ROOM 400
7 20 1 12 1/2 GUEST ROOM 403		8 20 1 12 1/2 GUEST ROOM 402
9 20 1 12 1/2 GUEST ROOM 403		10 20 1 12 1/2 GUEST ROOM 402
11 20 1 12 1/2 GUEST ROOM 403		12 20 1 12 1/2 GUEST ROOM 402
13 20 1 12 1/2 GUEST ROOM 405		14 20 1 12 1/2 GUEST ROOM 404
15 20 1 12 1/2 GUEST ROOM 405		16 20 1 12 1/2 GUEST ROOM 404
17 20 1 12 1/2 GUEST ROOM 405		18 20 1 12 1/2 GUEST ROOM 404
19 20 1 12 1/2 GUEST ROOM 407		20 20 1 12 1/2 GUEST ROOM 406
21 20 1 12 1/2 GUEST ROOM 407		22 20 1 12 1/2 GUEST ROOM 406
23 20 1 12 1/2 GUEST ROOM 409		24 20 1 12 1/2 GUEST ROOM 406
25 20 1 12 1/2 GUEST ROOM 409		26 20 1 12 1/2 GUEST ROOM 408
27 20 1 12 1/2 GUEST ROOM 409		28 20 1 12 1/2 GUEST ROOM 408
29 20 1 12 1/2 GUEST ROOM 409		30 20 1 12 1/2 GUEST ROOM 408
31 20 1 12 1/2 GUEST ROOM 410		32 20 1 12 1/2 GUEST ROOM 412
33 20 1 12 1/2 GUEST ROOM 410		34 20 1 12 1/2 GUEST ROOM 412
35 20 1 12 1/2 GUEST ROOM 410		36 20 1 12 1/2 GUEST ROOM 412
37 20 1 12 1/2 GUEST ROOM 413		38 20 1 12 1/2 GUEST ROOM 414
39 20 1 12 1/2 GUEST ROOM 413		40 20 1 12 1/2 GUEST ROOM 414
41 20 1 12 1/2 GUEST ROOM 413		42 20 1 12 1/2 GUEST ROOM 414
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 100A, MLO	PANEL "LD" (FOURTH FLR. GUEST RMS.)	MOUNTING: SURFACE A/C: 10K REMARKS: SECTION 2
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
43 20 1 12 1/2 GUEST ROOM 415		44 20 1 12 1/2 GUEST ROOM 416
45 20 1 12 1/2 GUEST ROOM 415		46 20 1 12 1/2 GUEST ROOM 416
47 20 1 12 1/2 GUEST ROOM 415		48 20 1 12 1/2 GUEST ROOM 416
49 20 1 12 1/2 GUEST ROOM 417		50 20 1 12 1/2 GUEST ROOM 418
51 20 1 12 1/2 GUEST ROOM 417		52 20 1 12 1/2 GUEST ROOM 418
53 20 1 12 1/2 GUEST ROOM 417		54 20 1 12 1/2 GUEST ROOM 418
55 20 1 12 1/2 GUEST ROOM 419		56 20 1 12 1/2 GUEST ROOM 420
57 20 1 12 1/2 GUEST ROOM 419		58 20 1 12 1/2 GUEST ROOM 420
59 20 1 12 1/2 GUEST ROOM 419		60 20 1 12 1/2 GUEST ROOM 420
61 20 1 12 1/2 GUEST ROOM 421		62 20 1 12 1/2 GUEST ROOM 422
63 20 1 12 1/2 GUEST ROOM 421		64 20 1 12 1/2 GUEST ROOM 422
65 20 1 12 1/2 GUEST ROOM 421		66 20 1 12 1/2 GUEST ROOM 422
67 20 1 12 1/2 GUEST ROOM 423		68 20 1 12 1/2 GUEST ROOM 424
69 20 1 12 1/2 GUEST ROOM 423		70 20 1 12 1/2 GUEST ROOM 424
71 20 1 12 1/2 GUEST ROOM 423		72 20 1 12 1/2 GUEST ROOM 424
73 20 1 12 1/2 GUEST ROOM 425		74 20 1 12 1/2 GUEST ROOM
75 20 1 12 1/2 GUEST ROOM 425		76 20 1 12 1/2 CORRIDOR LTS.
77 20 1 12 1/2 GUEST ROOM 425		78 20 1 12 1/2 CORRIDOR LTS.
79 20 1 12 1/2 VENDING RECEPT.		80 20 1 12 1/2 EMERG./EXIT LTS.
81 20 1 12 1/2 VENDING RECEPT.		82 20 1 12 1/2 CORRIDOR RECEPT.
83 20 1 12 1/2 VENDING LTS.		84 20 1 12 1/2 CORRIDOR RECEPT.
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		RE-E-10.0 FOR FEEDER CALCU.

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 100A, MLO	PANEL "LE" (FIFTH FLR. GUEST RMS.)	MOUNTING: SURFACE A/C: 10K REMARKS: SECTION 1 SUB FEED LUGS
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
1 20 1 12 1/2 GUEST ROOM 501		2 20 1 12 1/2 GUEST ROOM 500
3 20 1 12 1/2 GUEST ROOM 501		4 20 1 12 1/2 GUEST ROOM 500
5 20 1 12 1/2 GUEST ROOM 501		6 20 1 12 1/2 GUEST ROOM 500
7 20 1 12 1/2 GUEST ROOM 503		8 20 1 12 1/2 GUEST ROOM 502
9 20 1 12 1/2 GUEST ROOM 503		10 20 1 12 1/2 GUEST ROOM 502
11 20 1 12 1/2 GUEST ROOM 503		12 20 1 12 1/2 GUEST ROOM 502
13 20 1 12 1/2 GUEST ROOM 505		14 20 1 12 1/2 GUEST ROOM 504
15 20 1 12 1/2 GUEST ROOM 505		16 20 1 12 1/2 GUEST ROOM 504
17 20 1 12 1/2 GUEST ROOM 505		18 20 1 12 1/2 GUEST ROOM 504
19 20 1 12 1/2 GUEST ROOM 507		20 20 1 12 1/2 GUEST ROOM 506
21 20 1 12 1/2 GUEST ROOM 507		22 20 1 12 1/2 GUEST ROOM 506
23 20 1 12 1/2 GUEST ROOM 507		24 20 1 12 1/2 GUEST ROOM 506
25 20 1 12 1/2 GUEST ROOM 509		26 20 1 12 1/2 GUEST ROOM 508
27 20 1 12 1/2 GUEST ROOM 509		28 20 1 12 1/2 GUEST ROOM 508
29 20 1 12 1/2 GUEST ROOM 509		30 20 1 12 1/2 GUEST ROOM 508
31 20 1 12 1/2 GUEST ROOM 510		32 20 1 12 1/2 GUEST ROOM 512
33 20 1 12 1/2 GUEST ROOM 510		34 20 1 12 1/2 GUEST ROOM 512
35 20 1 12 1/2 GUEST ROOM 510		36 20 1 12 1/2 GUEST ROOM 512
37 20 1 12 1/2 GUEST ROOM 513		38 20 1 12 1/2 GUEST ROOM 514
39 20 1 12 1/2 GUEST ROOM 513		40 20 1 12 1/2 GUEST ROOM 514
41 20 1 12 1/2 GUEST ROOM 513		42 20 1 12 1/2 GUEST ROOM 514
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		USE 200A FEEDER

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 3000A, BREAKER	PANEL "MDP" (MAIN DISTRIBUTION PANEL)	MOUNTING: FREE STANDING A/C: 65K REMARKS: INSTALL ON 4" CONCRETE PAD
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
1 175 3 2/0 2 PANEL CA (1)		2 100 3 3 1/2 PANEL CB
3 - - 2/0 2 PANEL CA (1)		4 - - 3 1/2 PANEL CB
5 - - 2/0 2 PANEL CA (1)		6 - - 3 1/2 PANEL CB
7 125 3 2 1/4 PANEL CA (2)		8 200 3 3/0 2 PANEL LB (1)
9 - - 2 1/4 PANEL CA (2)		10 - - 3/0 2 PANEL LB (1)
11 - - 2 1/4 PANEL CA (2)		12 - - 3/0 2 PANEL LB (1)
13 300 3 350 3 PANEL LDY		14 200 3 3/0 2 PANEL LB (2)
15 - - 350 3 PANEL LDY		16 - - 3/0 2 PANEL LB (2)
17 - - 350 3 PANEL LDY		18 - - 3/0 2 PANEL LB (2)
19 225 3 4/0 2 1/2 PANEL FD		20 200 3 3/0 2 PANEL LC (1)
21 - - 4/0 2 1/2 PANEL FD		22 - - 3/0 2 PANEL LC (1)
23 - - 4/0 2 1/2 PANEL FD		24 - - 3/0 2 PANEL LC (1)
25 300 3 350 3 PANEL LA		26 200 3 3/0 2 PANEL LC (2)
27 - - 350 3 PANEL LA		28 - - 3/0 2 PANEL LC (2)
29 - - 350 3 PANEL LA		30 - - 3/0 2 PANEL LC (2)
31 400 3 500 4 PANEL PL		32 200 3 3/0 2 PANEL LD (1)
33 - - 500 4 PANEL PL		34 - - 3/0 2 PANEL LD (1)
35 - - 500 4 PANEL PL		36 - - 3/0 2 PANEL LD (1)
37 200 3 3/0 2 PANEL OL		38 200 3 3/0 2 PANEL LD (2)
39 - - 3/0 2 PANEL OL		40 - - 3/0 2 PANEL LD (2)
41 - - 3/0 2 PANEL OL		42 - - 3/0 2 PANEL LD (2)
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		

TYPE: SERVICE M/N: 100A	PANEL "MDP" (MAIN DISTRIBUTION PANEL)	MOUNTING: A/C: 10K REMARKS:
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
43 200 3 3/0 2 PANEL HB		44 200 3 3/0 2 PANEL LE(1)
45 - - 3/0 2 PANEL HB		46 - - 3/0 2 PANEL LE(1)
47 - - 3/0 2 PANEL HB		48 - - 3/0 2 PANEL LE(1)
49 200 3 3/0 2 PANEL HC		50 200 3 3/0 2 PANEL LE(2)
51 - - 3/0 2 PANEL HC		52 - - 3/0 2 PANEL LE(2)
53 - - 3/0 2 PANEL HC		54 - - 3/0 2 PANEL LE(2)
55 200 3 3/0 2 PANEL HD (1)		56 175 3 2/0 2 PANEL A
57 - - 3/0 2 PANEL HD (1)		58 - - 2/0 2 PANEL A
59 - - 3/0 2 PANEL HD (1)		60 - - 2/0 2 PANEL A
61 225 3 4/0 2 1/2 PANEL HD (2)		62 200 3 3/0 2 PANEL HE
63 - - 4/0 2 1/2 PANEL HD (2)		64 - - 3/0 2 PANEL HE
65 - - 4/0 2 1/2 PANEL HD (2)		66 - - 3/0 2 PANEL HE
67 150 3 1/0 1/2 BOOSTER PUMP (30 HP)		68 200 3 3/0 2 ELEVATOR
69 - - 1/0 1/2 BOOSTER PUMP (30 HP)		70 - - 3/0 2 ELEVATOR
71 - - 1/0 1/2 BOOSTER PUMP (30 HP)		72 - - 3/0 2 ELEVATOR
73 74 200 3 3/0 2 ELEVATOR		74 200 3 3/0 2 ELEVATOR
75 76 - - 3/0 2 ELEVATOR		76 - - 3/0 2 ELEVATOR
77 78 - - 3/0 2 ELEVATOR		78 - - 3/0 2 ELEVATOR
79 80		80
81 82		82
83 84		84
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		RE-SHEET E10.0 FOR LOAD ANALYSIS

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 100A, MLO	PANEL "LE" (FIFTH FLR. GUEST RMS.)	MOUNTING: SURFACE A/C: 10K REMARKS: SECTION 2
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
43 20 1 12 1/2 GUEST ROOM 515		44 20 1 12 1/2 GUEST ROOM 516
45 20 1 12 1/2 GUEST ROOM 515		46 20 1 12 1/2 GUEST ROOM 516
47 20 1 12 1/2 GUEST ROOM 515		48 20 1 12 1/2 GUEST ROOM 516
49 20 1 12 1/2 GUEST ROOM 517		50 20 1 12 1/2 GUEST ROOM 518
51 20 1 12 1/2 GUEST ROOM 517		52 20 1 12 1/2 GUEST ROOM 518
53 20 1 12 1/2 GUEST ROOM 517		54 20 1 12 1/2 GUEST ROOM 518
55 20 1 12 1/2 GUEST ROOM 519		56 20 1 12 1/2 GUEST ROOM 520
57 20 1 12 1/2 GUEST ROOM 519		58 20 1 12 1/2 GUEST ROOM 520
59 20 1 12 1/2 GUEST ROOM 519		60 20 1 12 1/2 GUEST ROOM 520
61 20 1 12 1/2 GUEST ROOM 521		62 20 1 12 1/2 GUEST ROOM 522
63 20 1 12 1/2 GUEST ROOM 521		64 20 1 12 1/2 GUEST ROOM 522
65 20 1 12 1/2 GUEST ROOM 521		66 20 1 12 1/2 GUEST ROOM 522
67 20 1 12 1/2 GUEST ROOM 523		68 20 1 12 1/2 GUEST ROOM 524
69 20 1 12 1/2 GUEST ROOM 523		70 20 1 12 1/2 GUEST ROOM 524
71 20 1 12 1/2 GUEST ROOM 523		72 20 1 12 1/2 GUEST ROOM 524
73 20 1 12 1/2 GUEST ROOM 525		74 20 1 12 1/2 GUEST ROOM
75 20 1 12 1/2 GUEST ROOM 525		76 20 1 12 1/2 CORRIDOR LTS.
77 20 1 12 1/2 GUEST ROOM 525		78 20 1 12 1/2 CORRIDOR LTS.
79 20 1 12 1/2 VENDING RECEPT.		80 20 1 12 1/2 EMERG./EXIT LTS.
81 20 1 12 1/2 VENDING RECEPT.		82 20 1 12 1/2 CORRIDOR RECEPT.
83 20 1 12 1/2 VENDING LTS.		84 20 1 12 1/2 CORRIDOR RECEPT.
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE		RE-E-10.0 FOR FEEDER CALCU.

TYPE: SQ D OR G.E. SERVICE: 120/208/3 M/N: 225 MLO	PANEL "A" (ROOF EQUIP.)	MOUNTING: SURFACE A/C: 10K REMARKS:
POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE	LOAD V. A. A B C E	POS. TRIP BRK. WIRE CD SERVICE NO. AMP. POLE SIZE
1 20 1 12 1/2 EF-2,4		2 20 1 12 1/2 ROOF RECEPT.
3 20 1 12 1/2 EF-1,3		4 20 1 12 1/2 ROOF RECEPT.
5 20 1 12 1/2 EF-5,7		6 20 1 12 1/2 ROOF RECEPT.
7 20 1 12 1/2 EF-6,8		8 20 1 12 1/2 ROOF RECEPT.
9 20 1 12 1/2 EF-9,12		10 20 1 12 1/2 DUCT DETECTOR
11 20 1 12 1/2 EF-10,11		12 20 1 12 1/2 DUCT DETECTOR
13 20 1 12 1/2 EF-14,17		14 20 1 12 1/2 DUCT DETECTOR
15 20 1 12 1/2 EF-13,15		16 30 2 10 1/2 PTAC
17 20 1 12 1/2 EF-16		18 - - 10 1/2 PTAC
19 20 1 12 1/2 EF-18,19		20 30 2 10 1/2 PTAC
21 20 1 12 1/2 EF-21		22 - - 10 1/2 PTAC
23 20 1 - - SPARE		24 20 1 - - SPARE
25 20 1 - - SPARE		26 20 1 - - SPARE
27 20 1 - - SPARE		28 20 1 - - SPARE
29 20 1 - - SPARE		30 20 1 - - SPARE
31 20 1 - - SPARE		32 20 1 - - SPARE
33 20 1 - - SPARE		34 20 1 - - SPARE
35 20 1 - - SPARE		36 20 1 - - SPARE
37 20 1 - - SPARE		38 20 1 - - SPARE
39 20 1 - - SPARE		40 20 1 - - SPARE
41 20 1 - - SPARE		42 20 1 - - SPARE
CONNECTED V.A. PER PHASE TOTAL AMPS PER PHASE	13650 15300 14900 114 129 124	WIRE AMPS-125x129-161 USE 175A FEEDER, 2" C., 4" 2/0, 1#6G.

SYMBOL SCHEDULE AND NOTES	
SYMBOL	DESCRIPTION
	FLUORESCENT LAY-IN OR SURFACE MOUNTED LIGHTING FIXTURE.
	FLUORESCENT FIXTURE WITH INVERTER BATTERY BACK-UP.
	WALL MOUNTED LIGHTING FIXTURE.
	EXIT LIGHT FIXTURE. CEILING AND WALL MOUNTED. SHADED QUADRANT INDICATES LIGHTED FACE. ARROW INDICATES DIRECTION OF EGRESS.
	JUNCTION BOX. CEILING OR FLOOR MOUNTED AS INDICATED ON DRAWINGS.
	OCCUPANCY SENSOR
	SINGLE POLE, SINGLE THROW TOGGLE WALL SWITCH. MOUNT 48" A.F.F. TO CENTER.
	LIGHT SWITCH WITH DIMMER CONTROL
	SINGLE POLE, SINGLE THROW TOGGLE WALL SWITCH WITH PILOT LIGHT. MOUNT 48" A.F.F.
	SINGLE POLE, DOUBLE THROW "THREE-WAY" TOGGLE WALL SWITCH. MOUNT 48" A.F.F.
	FAN SWITCH
	NON-FUSED DISCONNECT SWITCH RATED 30 AMPS UNLESS NOTED OTHERWISE.
	DUPLEX RECEPTACLE MOUNTED ABOVE COUNTERTOP HEIGHT.
	DUPLEX RECEPTACLE MOUNTED 18" A.F.F. UNLESS NOTED OTHER WISE. MOUNT WITH LONG DIMENSION VERTICAL UNLESS NOTED OTHERWISE.
	DUPLEX RECEPTACLE MOUNTED 18" A.F.F. UNLESS NOTED OTHER WISE. MOUNT WITH LONG DIMENSION. LOWER 1/2 OF RECEPTACLE SWITCHED, UPPER 1/2 UNSWITCHED
	QUADRAPLEX RECEPTACLE MOUNTED 18" AFF UNLESS OTHERWISE. MOUNT WITH LONG DIMENSION VERTICAL.
	FLOOR OUTLET W/ DUPLEX RECEPTACLE
	HVAC THERMOSTAT LOCATION WITH 2x4 VERTICAL BOX 48" AFF. PROVIDE 3/4" CONDUIT TO ABOVE CEILING. WIRING BY MECHANICAL CONTRACTOR.
	WEATHERPROOF
	DUPLEX RECEPTACLE WITH INTEGRAL PERSONNEL GROUND FAULT CIRCUIT INTERRUPTER (GFCI).
	EMERGENCY BATTERY BACK UP FIXT.- CONNECT TO NEAREST UNSWITCHED LIGHT CKT. -MT ON WALL 84" AFF LITHONIA #BELM2 TH N "QUANTUM" SERIES.
	RECESSED OR CEILING MOUNTED FIXTURE- SURFACE OR RECESSED, SEE FIXTURE SCHEDULE
	HOME RUN TO PANEL
	FUSED DISCONNECT FUSED AS NOTED
	DISTRIBUTION PANEL
	MOTOR
	PUSH BUTTON
	FIRE ALARM SYSTEM ANNUNCIATOR
	ACCESSIBLE GUEST ROOM SMOKE DETECTOR HARD WIRED AND EQUIPPED WITH LOCAL ANNUNCIATOR AND INTEGRAL VISUAL STROBE LIGHT WITH LIGHT INTENSITY OF 177cd.- WALL MTD 12" FROM CLG. PROVIDED BY ELECTRICAL CONTRACTOR.
	FIRE ALARM SYSTEM STROBE LIGHT-- MTD 80" AFF
	FIRE ALARM SYSTEM MINIHORN/STROBE IN GUESTROOM IF REQUIRED BY LOCAL CODE AUTHORITIES.
	FIRE ALARM SYSTEM DUCT SMOKE DETECTOR
	TELEVISION SYSTEM OUTLET-PROVIDE 2"x4" VERTICAL BOX 18" AFF WITH 1"C TO ABOVE ACCESSIBLE CORRIDOR CEILING. WIRING BY OTHERS
	TELEPHONE SYSTEM OUTLET-PROVIDE 2"x4" VERTICAL BOX 18" AFF UNLESS OTHERWISE NOTED. PROVIDE RJ-45 TELEPHONE JACK, 3/4" CONDUIT TO ABOVE ACCESSIBLE CORRIDOR CEILING WITH CAT 5E CABLE TO TELEPHONE EQUIPMENT.
	TELEPHONE SYSTEM OUTLET WITH DATA PORT. PROVIDE 2"x4" VERTICAL BOX 18" AFF UNLESS OTHERWISE NOTED. PROVIDE RJ-45 TELEPHONE AND DATA JACK, 3/4" CONDUIT TO ABOVE ACCESSIBLE CORRIDOR CEILING WITH CAT 5E CABLE TO TELEPHONE EQUIPMENT.
	FIRE ALARM SYSTEM HEAT DETECTOR
	CARBON MONOXIDE DETECTOR
	FIRE ALARM SYSTEM CONTROL PANEL
	FIRE ALARM SYSTEM BREAKGLASS STATION- MTD 48" AFF
	STANDARD GUESTROOM SMOKE DETECTOR HARD WIRED AND LOCALLY ANNUNCIATED WITHIN EACH ROOM. MOUNT ON EXTERIOR OF GUESTROOM BATH WALL, 12" BELOW CEILING. PROVIDED BY ELECTRICAL CONTRACTOR.
	FIRE ALARM SYSTEM MAGNETIC DOOR HOLDER
	FIRE ALARM SYSTEM AUDIO/VISUAL DEVICE- MTD 80" AFF