

Energy Code:

Location: Construction Type: Conditioned Floor Area:

Glazing Area Percentage: Heating Degree Days: Climate Zone:

2006 IECC

Monroe (Quachita), Louisiana

Multifamily 49920 ft2 17% 2407

Construction Site:

Owner/Agent:

Designer/Contractor:

Richard Molenaar

Richard Molenaar, Architect 4355 Burnette Place Memphis, TN 38141 901-794-6117

richardmolenaar@comcast.net

Compliance: Passes on UA trade-off

Compliance: 6.5% Better Than Code

Maximum UA: 22453

Your UA: 20986

Maximum SHGC: 0.40 Your SHGC: 0.38

The % Better or Worse Than Code index reflects how close to compliance the house is based on code trade-off rules.

It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	Glazing or Door U-Factor	UA
Wall 1: Wood Frame, 16" o.c.	25200	10.0	11.0		919
Window 1: Metal Frame:Double Pane with Low-E SHGC: 0.38	4170			0.530	2210
Door 1: Glass SHGC: 0.57	105			0.570	60
Door 2: Solid	42			1.000	42
Ceiling 1: Flat Ceiling or Scissor Truss	16640	0.0	38.0		416
Floor 1: Slab-On-Grade:Unheated Insulation depth: 0.0'	16640		0.0		17339

Boiler 1: Other (Except Gas-Fired Steam) 90 AFUE Air Conditioner 1: Electric Central Air 13 SEER

Compliance Statement: The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2006 IECC requirements in REScheck Version 4.4.1 and to comply with the mandatory requirements listed in the REScheck Inspection Checklist.

Project Title:

Data filename: C:\Documents and Settings\Robert Powell\My Documents\REScheck\monroe hampton.rck

Report date: 02/01/11

Page 1 of 3