

COMBUSTION AIR REQ'D:
- PROVIDE 1 CFM PER BTU
TOTAL COMB. AIR REQ'D:
- PROVIDE 2-1/2"X12" SCREENED
COMBUSTION AIR VENTS IN WALL
- 1 WITHIN 12' OF CEILING
- 1 WITHIN 12' OF FLOOR

NOTE:
POOL/SPA AREA DEHUMIDIFIER SHALL
BE DESIGN/BUILD BY MECHANICAL
CONTRACTOR. VERIFY POOL/SPA AREA
PRIOR TO BIDDING.

FULLY COVERED DOOR
- REFER TO SHEET A4


- NOTE:
1. ALL DUCTWORK RUN BETWEEN
JOISTS WHERE POSSIBLE.
- DUCTS SHALL BE RUN WITHIN
SOFFIT FRAMING WHERE POSSIBLE
2. OPENINGS FOR DUCTWORK,
RUN THRU JOISTS SHALL BE
COORDINATED WITH
STRUCTURAL FRAMING
SYSTEM DEPTH LIMITS MAY
REQUIRE ALTERNATE
ROUTING).
3. FD = FIRE/SMOKE DAMPER
4. * INDICATES DOOR TO BE UNDERCUT 1"
5. PROVIDE SMOKE DETECTOR ACTIVATED
SHUT-OFF CONTROL IN MAIN SUPPLY AIR
DUCT OF MECH UNIT FOU-1
6. REFER TO MECHANICAL EQUIPMENT LIST
ON SHEET M6 FOR ALL HVAC EQUIPMENT

NOTE:
CROSS-HATCHED WALLS AND ENTIRE
FLOOR/CEILING ASSEMBLIES OF LAMINARY ROOM, STOR. ROOMS,
ELEVATOR SHAFTS, ELEVATOR ENCLOSURES, STAIRWAYS,
FIRE RESISTIVE CONSTRUCTION FOR OCCUPANCY SEPARATION
PURPOSES. (2-HR. @ ELEVATOR SHAFT, STAIRWAY ENCLOSURES
& LINEN CLOSET SHAFT)

ENLARGED LOBBY AREA MECHANICAL FLOOR PLAN

SCALE: 1/4"=1'-0"

REVISIONS PER
CITY OF SOUTH SAN FRANCISCO



by	date
drawn	
checked	
revised	
project no.	
sheet	
set no.	

PROPOSED:
HAMPTON INN
CORPORATE DRIVE
SOUTH SAN FRANCISCO, CALIFORNIA

THESE DRAWINGS, DESIGNS, SKETCHES,
IDEAS & ARRANGEMENTS ARE THE SOLE &
EXCLUSIVE PROPERTY OF LEE GAGE & ASSOCIATES,
AND WERE CREATED AND DEVELOPED BY AND FOR THE
ARCHITECT'S EXCLUSIVE USE ON AND IN CONJUNCTION
WITH THE ARCHITECT'S WORK. NOTHING CONTAINED
HEREIN SHALL BE REPRODUCED OR TRANSMITTED IN ANY
FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL,
INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY
INFORMATION STORAGE AND RETRIEVAL SYSTEM,
WITHOUT THE WRITTEN CONSENT OF LEE GAGE & ASSOCIATES.

lee gage & associates
architects • engineers • planners

7636 n. ingram suite 107 fresno, california 93711 phone (209) 439-2222

© LEE GAGE & ASSOC.