

NOTE:
CROSS-HATCHED WALLS AND ENTIRE FLOOR/CEILING ASSEMBLIES OF LAUNDRY ROOM, STOR. ROOMS, & 2ND FLOOR SERVICE ROOM SHALL BE OF F-IR-150 FIRE RESISTIVE CONSTRUCTION FOR COUP-FIRE SEPARATION FROM OTHER AREAS. ALL OTHER AREAS SHALL BE OF F-IR-150 FIRE RESISTIVE CONSTRUCTION WITH FIRE RESISTANCE OF MINIMUM 1 HOUR. ALL PENETRATIONS IN THESE AREAS TO BE STOP SEALANT (ASTM E-914/UL #1479).

REFER TO ARCHITECTURAL DRAWINGS FOR DESIGNATION & LISTING OF FIRE RATED ASSEMBLY DESIGN NUMBERS. COORDINATE ELECTRICAL REQUIREMENTS WITH FIRE RESISTANCE OF WALLS, CEILING AND CONSTRUCTION.

REFER TO SHEET E1 FOR TYPICAL NOTES & DETAILS.

REFER TO SHEET E4 & E4B FOR TYPICAL GUEST ROOM LAYOUTS.

REFER TO SHEET E5 FOR LIGHTING SCHEDULE.


REFER TO SHEETS E6, E7 & E8 FOR PANEL SCHEDULES.

REFER TO SHEET E9 FOR SINGLE LINE DIAGRAMS & DETAILS.

NOTE TO SPA DESIGNER/BUILDER:
ALL ELECTRICAL INSTALLATIONS, EQUIPMENT & LOCATIONS IN POOL & SPA AREA TO COMPLY W/ANSI/ISO ARTICLE 650. PROVIDE 15 MINUTE OPERATING TIMER W/EMERGENCY SHUT-OFF SWITCH THAT CONTROLS THE JET'S & THE RE-CIRCULATION PUMP. (LOCATE IN A CONSPICUOUS LOCATION)

ENLARGED LOBBY AREA ELECTRICAL FLOOR PLAN

SCALE: 1/4"=1'-0"



LEE GAGE C-6718

THESE DRAWINGS, DESIGNS, SKETCHES, IDEAS & ARRANGEMENTS ARE THE SOLE & EXCLUSIVE PROPERTY OF LEE GAGE & ASSOCIATES, AND WERE CREATED AND DEVELOPED BY AND FOR THE ARCHITECT'S EXCLUSIVE USE ON AND IN CONJUNCTION WITH THE ARCHITECT'S WORK. NOTHING CONTAINED OR REPRESENTED ON THESE DOCUMENTS SHALL BE USED BY OR DISCLOSED TO ANY PERSON, FIRM OR CORPORATION FOR ANY PURPOSE WITHOUT EXPRESSED WRITTEN CONSENT OF LEE GAGE & ASSOCIATES.

lee gage & associates architects • engineers • planners

7636 n. ingram suite 107 fresno, california 93711 phone (209) 439-2222

© LEE GAGE & ASSOC.

by _____ date _____

drawn _____

checked _____

revised _____

revised _____

project no. _____

sheet no. **E3**