


KEY NOTES:


- 1 PROVIDE 115V POWER FOR RECIRCULATING PUMPS (1/4HP/2 RECD.) (WATER HEATERS) - VERIFY REQUIREMENTS
- 2 ELEVATOR DISCONNECT SWITCH - PROVIDE 1 DISCONNECT FOR E.A. ELEVATOR - PROVIDE 1 DISCONNECT FOR ELEVATOR EQUIP. (VERIFY REQTS. W/ELEVATOR COMPANY)

NOTE:
GROSS-WATCHED WALLS AND ENTIRE 1ST FLOOR SERVICE AREAS (LAUNDRY ROOM, STOR. ROOMS, & 2ND FLOOR SERVICE ROOM) SHALL BE OF 1-HR. FIRE RESISTIVE CONSTRUCTION FOR OCCUPANCY SEPARATION PURPOSES. (2-HR @ ELEVATOR SHAFT & STAIRWAY ENCLOSURES) - ALL PENETRATIONS IN THESE AREAS TO BE FIRE-STOPPED WITH UL111 #65240 FIRE STOP SEALANT (ASTM E-814/ UL #479)
REFER TO ARCHITECTURAL DRAWINGS FOR DESIGNATION & LISTING OF FIRE RATED ASSEMBLY DESIGN NUMBERS, COORDINATE ELECTRICAL REQUIREMENTS WITH FIRE RESISTANCE OF MATERIALS AND CONSTRUCTION.
REFER TO SHEET E1 FOR TYPICAL NOTES & REQTS. NOT LISTED HERE
REFER TO SHEET E4 FOR TYPICAL GUEST ROOM LAYOUTS
REFER TO SHEET E5 FOR LIGHTING SCHEDULE
REFER TO SHEETS E6, E7 & E8 FOR PANEL SCHEDULES
REFER TO SHEET E9 FOR SINGLE LINE DIAGRAMS & DETAILS



ENLARGED LAUNDRY AREA ELECTRICAL FLOOR PLAN

SCALE: 1/4"=1'-0"



LEE GAGE C-6718

Sheet SET NO. **E3B**

Project no. _____
revised _____
checked _____
drawn _____
by _____
date _____

PROPOSED:
HAMPTON INN
CORPORATE RESIDENCES
SOUTH SAN FRANCISCO, CALIFORNIA

THESE DRAWINGS, DESIGNS, SKETCHES, IDEAS & ARRANGEMENTS ARE THE SOLE & EXCLUSIVE PROPERTY OF LEE GAGE & ASSOCIATES, AND WERE CREATED AND DEVELOPED BY AND FOR THE ARCHITECT'S EXCLUSIVE USE ON AND IN CONJUNCTION WITH THE ARCHITECT'S WORK. NOTHING CONTAINED OR REPRESENTED ON THESE DOCUMENTS SHALL BE USED BY OR DISCLOSED TO ANY PERSON, FIRM OR CORPORATION FOR ANY PURPOSE WITHOUT EXPRESSED WRITTEN CONSENT OF LEE GAGE & ASSOCIATES.

lee gage & associates
architects • engineers • planners
7636 n. ingram suite 107 fresno, california 93711 phone (209) 439-2222

© LEE GAGE & ASSOC.