



803 S. MOUNT MORIAH
SUITE 100B
MEMPHIS, TN 38117
(901) 863-1715
(901) 863-2851
info@jwarchitects.com

NO.	ISSUED	DATE
1	ISSUED	10/26/07

NO.	REVISIONS	DATE
CONTRACT PARTS		
STRUCTURAL:		
SK INTERPRETAL, INC.		
130 SOUTH MAIN STREET		
HUNTSVILLE, AL 35811		
(256) 862-3098		
MECHANICAL:		
CRABTREE ENGINEERING		
726 S. MT. MORIAH		
MEMPHIS, TN 38117		
(901) 767-9888		
ELECTRICAL:		
CHS ENGINEERING		
726 S. MT. MORIAH		
MEMPHIS, TN 38117		
(901) 767-2857		
SEAL		

DATE	10/26/07
DRAWN BY	JSH
CHECKED BY	CHS
FILE NAME	
SCALE	NONE
PROJECT NO.	1507

DRAWING

SHEET NAME
PANEL SCHEDULE
BOSSIER CITY,
LOUISIANA
Holiday Inn
MILLENNIUM

Panel	ROOM STORAGE ROOM	VOLTS 280V/120, 3P, 4W	MAN BRK. I.M.O	AC 22000	
M3					
MOUNTING SURFACE					
FED FROM MSB					
NEUTRAL 100%					
SECTION 1					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	8.4
23	50/3	11.8	23	10	8.4
24	50/3	11.8	24	10	8.4
25	50/3	11.8	25	10	8.4
26	50/3	11.8	26	10	8.4
27	50/3	11.8	27	10	8.4
28	50/3	11.8	28	10	8.4
29	50/3	11.8	29	10	8.4
30	50/3	11.8	30	10	8.4
31	50/3	11.8	31	10	8.4
32	50/3	11.8	32	10	8.4
33	50/3	11.8	33	10	8.4
34	50/3	11.8	34	10	8.4
35	50/3	11.8	35	10	8.4
36	50/3	11.8	36	10	8.4
37	50/3	11.8	37	10	8.4
38	50/3	11.8	38	10	8.4
39	50/3	11.8	39	10	8.4
40	50/3	11.8	40	10	8.4
41	50/3	11.8	41	10	8.4
42	50/3	11.8	42	10	8.4
SECTION 2					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	8.4
23	50/3	11.8	23	10	8.4
24	50/3	11.8	24	10	8.4
25	50/3	11.8	25	10	8.4
26	50/3	11.8	26	10	8.4
27	50/3	11.8	27	10	8.4
28	50/3	11.8	28	10	8.4
29	50/3	11.8	29	10	8.4
30	50/3	11.8	30	10	8.4
31	50/3	11.8	31	10	8.4
32	50/3	11.8	32	10	8.4
33	50/3	11.8	33	10	8.4
34	50/3	11.8	34	10	8.4
35	50/3	11.8	35	10	8.4
36	50/3	11.8	36	10	8.4
37	50/3	11.8	37	10	8.4
38	50/3	11.8	38	10	8.4
39	50/3	11.8	39	10	8.4
40	50/3	11.8	40	10	8.4
41	50/3	11.8	41	10	8.4
42	50/3	11.8	42	10	8.4
SECTION 3					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	8.4
23	50/3	11.8	23	10	8.4
24	50/3	11.8	24	10	8.4
25	50/3	11.8	25	10	8.4
26	50/3	11.8	26	10	8.4
27	50/3	11.8	27	10	8.4
28	50/3	11.8	28	10	8.4
29	50/3	11.8	29	10	8.4
30	50/3	11.8	30	10	8.4
31	50/3	11.8	31	10	8.4
32	50/3	11.8	32	10	8.4
33	50/3	11.8	33	10	8.4
34	50/3	11.8	34	10	8.4
35	50/3	11.8	35	10	8.4
36	50/3	11.8	36	10	8.4
37	50/3	11.8	37	10	8.4
38	50/3	11.8	38	10	8.4
39	50/3	11.8	39	10	8.4
40	50/3	11.8	40	10	8.4
41	50/3	11.8	41	10	8.4
42	50/3	11.8	42	10	8.4
SECTION 4					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	8.4
23	50/3	11.8	23	10	8.4
24	50/3	11.8	24	10	8.4
25	50/3	11.8	25	10	8.4
26	50/3	11.8	26	10	8.4
27	50/3	11.8	27	10	8.4
28	50/3	11.8	28	10	8.4
29	50/3	11.8	29	10	8.4
30	50/3	11.8	30	10	8.4
31	50/3	11.8	31	10	8.4
32	50/3	11.8	32	10	8.4
33	50/3	11.8	33	10	8.4
34	50/3	11.8	34	10	8.4
35	50/3	11.8	35	10	8.4
36	50/3	11.8	36	10	8.4
37	50/3	11.8	37	10	8.4
38	50/3	11.8	38	10	8.4
39	50/3	11.8	39	10	8.4
40	50/3	11.8	40	10	8.4
41	50/3	11.8	41	10	8.4
42	50/3	11.8	42	10	8.4
SECTION 5					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	8.4
23	50/3	11.8	23	10	8.4
24	50/3	11.8	24	10	8.4
25	50/3	11.8	25	10	8.4
26	50/3	11.8	26	10	8.4
27	50/3	11.8	27	10	8.4
28	50/3	11.8	28	10	8.4
29	50/3	11.8	29	10	8.4
30	50/3	11.8	30	10	8.4
31	50/3	11.8	31	10	8.4
32	50/3	11.8	32	10	8.4
33	50/3	11.8	33	10	8.4
34	50/3	11.8	34	10	8.4
35	50/3	11.8	35	10	8.4
36	50/3	11.8	36	10	8.4
37	50/3	11.8	37	10	8.4
38	50/3	11.8	38	10	8.4
39	50/3	11.8	39	10	8.4
40	50/3	11.8	40	10	8.4
41	50/3	11.8	41	10	8.4
42	50/3	11.8	42	10	8.4
SECTION 6					
CKT	CKT	LOAD	CKT	LOAD	
#	BRK	KVA	#	BRK	KVA
1	50/3	11.8	1	2	2
2	50/3	11.8	2	201	4.4
3	50/3	11.8	3	6	10.1
4	50/3	11.8	4	8	8.4
5	50/3	11.8	5	10	8.4
6	50/3	11.8	6	10	8.4
7	50/3	11.8	7	10	8.4
8	50/3	11.8	8	10	8.4
9	50/3	11.8	9	10	8.4
10	50/3	11.8	10	10	8.4
11	50/3	11.8	11	10	8.4
12	50/3	11.8	12	10	8.4
13	50/3	11.8	13	10	8.4
14	50/3	11.8	14	10	8.4
15	50/3	11.8	15	10	8.4
16	50/3	11.8	16	10	8.4
17	50/3	11.8	17	10	8.4
18	50/3	11.8	18	10	8.4
19	50/3	11.8	19	10	8.4
20	50/3	11.8	20	10	8.4
21	50/3	11.8	21	10	8.4
22	50/3	11.8	22	10	