



CIVIL:
Benchmark Engineering and Surveying
101 Highpointe Court, Suite B
Brandon, MS 39042
Phone: (601) 591-1077
Fax: (601) 591-0177
Email: mikebes@bellsouth.net

MEP:
Allied Consulting Engineers
2905-D Queen City Drive
Charlotte, NC 28208
Phone: (704) 399-3943
Email: asoler@allied-engineers.com

Information contained on this drawing and in all digital files associated is authorized for use on the project named herein only and is the property of MISHRA ARCHITECTURE PLLC and may not be reproduced in any manner without express written or verbal permission from authorized individuals. Original drawing is 24"x36" and scales are as indicated. © 2013 MISHRA ARCHITECTURE PLLC



Holiday Inn Express
& Suites

Drawing Title

Phase
Construction Documents

Holiday Inn Express & Suites

1	FAN MFR. WALL CAP.	9	ROUTE 1" COND DOWN AND DUMP INTO MOP SINK.
2	48"x36" RUSKIN ELF 375 MAKE-UP/COMBUSTION AIR LOUVER W/ 48"x36"x30" FULLY INSULATED PLENUM AND MOTOR OPERATED DAMPER. DAMPER SHALL REMAIN IN CLOSED POSITION AND OPEN UP FULLY WHEN DRYERS ARE IN USE.	10	ROUTE 1" & ¾" COND DOWN AT WALL DUMP INTO FLOOR SINK. FLOOR SINK BY P.C.
3	SINGLE WALL RIGID SHEET METAL DRYER VENTS, SIZED PER MANUFACTURER. VENT CAP BY M.C. VERIFY SIZE W/ DRYER MANUFACTURER.	11	ROUTE 1" DOWN IN WALL AND OUT OF BUILDING TO CONDENSATE DRY WELL.
4	24"x12" RUSKIN ELF375 OUTSIDE AIR INTAKE LOUVER W/ 24"x12"x18" FULLY INSULATED PLENUM.		
5	12"x12" RUSKIN ELF375 OUTSIDE AIR INTAKE LOUVER W/ 12"x12"x12" FULLY INSULATED PLENUM.		
6	ROUTE ¾" CONDENSATE DOWN TO FLOOR DRAIN. FLOOR DRAIN BY P.C.		
7	ROUTE 1" CONDENSATE DOWN TO FLOOR DRAIN. FLOOR DRAIN BY P.C.		
8	ROUTE 1" CONDENSATE DOWN IN WALL AND THE INTO SINK TAILPIECE.		

[illegible]

1 MECHANICAL 1ST FLOOR PLAN
M101 SCALE: 1/8" = 1'-0"

Project No.	14-081	Sheet No. M101
Prepared by	CRM	
Checked by	EDB	
Date	Feb. 27, 2015	