

GeoEngineering Consultants (GEC) 4125 Blackford Avenue, Suite 145 San Jose, CA 95117

Phone: 925-321-5550

December 20, 2017 Project No. P16-0122

Mr. VJ Patel Southern Hospitality Services, LLC Holiday Inn Express 2834 El Camino Real Redwood City, California 94061

Subject: Proposed New Hotel

550 Gateway Boulevard / Proposed Hotel

South San Francisco, California

Respond to the Geotechnical Review

Dear Mr. Patel:

GEC received 2nd plan review comments for the propose hotel at the subject site, from the City reviewer, WC3 dated November 29, 2019. The CSA has requested clarification for the project.

For sake of simplicity and clarity, we replicate the comments made by the CSA followed by our answer.

Comment No. 1: "PC2: The plans indicate a neat diameter of 16 inches. The required spacing would be 48 inches. The details show a center-to-center spacing of 48 inches. Please verify with the geotechnical engineer that an edge-to-edge spacing of 48 inches is not required."

Response: GEC confirms that 3 diameter spacing is center to center and 48 inches spacing should be calculated from center of each pile to the center of adjacent pile."

Sincerely

GeoEngineering Consultant

Kamran Ghiassi, Ph.D., P.E., G.E. Principal Geotechnical Engineer