

BUILDING ENERGY ANALYSIS REPORT

PROJECT:

Gateway Hotel
550 Gateway Boulevard
South San Francisco, CA 94080

Project Designer:

Arris Studio Architects
1306 Johnson Avenue
San Luis Obispo, CA 93401
(805) 547-2240

Report Prepared by:

Tyler D. Reynolds
JVA Mechanical Engineering
510 State Street, Suite 285
Santa Barbara, CA 93101
(805) 543-3190



Job Number:

M16095

Date:

10/14/2017

The EnergyPro computer program has been used to perform the calculations summarized in this compliance report. This program has approval and is authorized by the California Energy Commission for use with both the Residential and Nonresidential 2016 Building Energy Efficiency Standards.

This program developed by EnergySoft Software – www.energysoft.com.

TABLE OF CONTENTS

Cover Page	1
Table of Contents	2
Form PRF-01-E Certificate of Compliance	3
Form ENV-MM Envelope Mandatory Measures	35
HVAC System Heating and Cooling Loads Summary	36

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 1 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

A. PROJECT GENERAL INFORMATION					
1.	Project Location (city)	South San Francisco	8.	Standards Version	Compliance2016
2.	CA Zip Code	94080	9.	Compliance Software (version)	EnergyPro 7.1
3.	Climate Zone	3	10.	Weather File	SAN-FRANCISCO-INTL_724940_CZ2010.epw
4.	Total Conditioned Floor Area in Scope	94,027 ft²	11.	Building Orientation (deg)	(W) 315 deg
5.	Total Unconditioned Floor Area	217 ft²	12.	Permitted Scope of Work	NewEnvelopeAndMechanical
6.	Total # of Stories (Habitable Above Grade)	6	13	Building Type(s)	Hotel-Motel
7.	Total # of dwelling units	11	14	Gas Type	NaturalGas

B. COMPLIANCE RESULTS FOR PERFORMANCE COMPONENTS (Annual TDV Energy Use, kBtu/ft ² -yr)					\$ 140.1
BUILDING COMPLIES					
1. Energy Component	2. Standard Design (TDV)	3. Proposed Design (TDV)	4. Compliance Margin (TDV)	5. Percent Better than Standard	
Space Heating	11.66	12.29	-0.63	-5.4%	
Space Cooling	7.50	9.60	-2.10	-28.0%	
Indoor Fans	17.23	10.11	7.12	41.3%	
Heat Rejection	0.15	--	0.15	--	
Pumps & Misc.	1.80	--	1.80	--	
Domestic Hot Water	3.33	2.70	0.63	18.9%	
Indoor Lighting	36.53	36.53	--	0.0%	
COMPLIANCE TOTAL	78.20	71.23	6.97	8.9%	
Receptacle	38.35	38.35	0.0	0.0%	
Process	0.88	0.88	0.0	0.0%	
Other Ltg	--	--	--	--	
TOTAL	117.43	110.46	7.0	5.9%	

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 2 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

C. PRIORITY PLAN CHECK/ INSPECTION ITEMS (in order of highest to lowest TDV energy savings)

1st	Indoor Fans: Check envelope and mechanical	<p>Compliance Margin By Energy Component (from Table B column 4)</p>
2nd	Pumps & Misc.: Check mechanical	
3rd	Domestic Hot Water: Check mechanical	
4th	Heat Rejection: Check envelope and mechanical	
5th	Indoor Lighting: Check lighting	
6th	Space Heating: Check envelope and mechanical	
7th	Space Cooling: Check envelope and mechanical	

D. EXCEPTIONAL CONDITIONS

The project shows partial compliance, either envelope only or mechanical only, excluding lighting systems. The building must show partial compliance including lighting or full new building compliance or show prescriptive lighting compliance before operation

This project includes Domestic Hot Water in the analysis. Please verify that Domestic Hot Water is included in the design for the permitted scope of work.

E. HERS VERIFICATION

This Section Does Not Apply

F. ADDITIONAL REMARKS

None Provided

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 3 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

G. COMPLIANCE PATH & CERTIFICATE OF COMPLIANCE SUMMARY			
Identify which building components use the performance or prescriptive path for compliance. "NA"= not in project			
For components that utilize the performance path, indicate the sheet number that includes mandatory notes on plans.			
Building Component	Compliance Path	Compliance Forms (required for submittal)	Location of Mandatory Notes on Plans
Envelope	<input checked="" type="checkbox"/> Performance	NRCC-PRF-ENV-DETAILS (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-ENV-01 / 02 / 03 / 04 / 05 / 06-E	
	<input type="checkbox"/> NA		
Mechanical	<input checked="" type="checkbox"/> Performance	NRCC-PRF-MCH-DETAILS (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-MCH-01 / 02 / 03 / 04 / 05 / 06 / 07-E	
	<input type="checkbox"/> NA		
Domestic Hot Water	<input checked="" type="checkbox"/> Performance	NRCC-PRF-PLB-DETAILS (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-PLB-01-E	
	<input type="checkbox"/> NA		
Lighting (Indoor Conditioned)	<input type="checkbox"/> Performance	NRCC-PRF-LTI-DETAILS (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-LTI-01 / 02 / 03 / 04 / 05-E	
	<input checked="" type="checkbox"/> NA		
Covered Process: Commercial Kitchens	<input type="checkbox"/> Performance	S2 (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-PRC-01/ 03-E	
	<input checked="" type="checkbox"/> NA		
Covered Process: Computer Rooms	<input type="checkbox"/> Performance	S3 (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-PRC-01/ 04-E	
	<input checked="" type="checkbox"/> NA		
Covered Process: Laboratory Exhaust	<input type="checkbox"/> Performance	S4 (section of the NRCC-PRF-01-E)	
	<input type="checkbox"/> Prescriptive	NRCC-PRC-01/ 09-E	
	<input checked="" type="checkbox"/> NA		

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 4 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

G. COMPLIANCE PATH & CERTIFICATE OF COMPLIANCE SUMMARY							
The following building components are only eligible for prescriptive compliance. Indicate which are relevant to the project.				The following building components may have mandatory requirements per Part 6. Indicate which are relevant to the project.			
Yes	NA	Prescriptive Requirement	Compliance Forms	Yes	NA	Mandatory Requirement	Compliance Forms
<input checked="" type="checkbox"/>	<input type="checkbox"/>	Lighting (Indoor Unconditioned) §140.6	NRCC-LTI-01 / 02 / 03 / 04 / 05-E	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Commissioning: §120.8 Simple Systems	NRCC-CXR-01 / 02 / 03 / 05-E
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lighting (Outdoor) §140.7	NRCC-LTO-01 / 02 / 03-E	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Complex Systems	NRCC-CXR-01 / 02 / 04 / 05-E
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Lighting (Sign) §140.8	NRCC-LTS-01-E	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Electrical: §130.5	NRCC-ELC-01-E
<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solar Thermal Water Heating: §140.5	NRCC-STH-01-E	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Solar Ready: §110.10	NRCC-SRA-01 / 02-E
<input type="checkbox"/>	<input checked="" type="checkbox"/>			<input type="checkbox"/>	<input checked="" type="checkbox"/>	Covered Process: §120.6	NRCC-PRC-01-E
				<input type="checkbox"/>	<input checked="" type="checkbox"/>	Parking Garage	NRCC-PRC-02-E
				<input type="checkbox"/>	<input checked="" type="checkbox"/>	Commercial Refrigeration	NRCC-PRC-05-E
				<input type="checkbox"/>	<input checked="" type="checkbox"/>	Warehouse Refrigeration	NRCC-PRC-06/07/08-E
				<input type="checkbox"/>	<input checked="" type="checkbox"/>	Compressed Air	NRCC-PRC-10-E
				<input type="checkbox"/>	<input checked="" type="checkbox"/>	Process Boilers	NRCC-PRC-11-E

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 5 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

H. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCI/NRCA/NRCV) – Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G. and H. in MCH and LTI Details Sections for Acceptance Tests and forms by equipment.		Confirmed	
Building Component	Compliance Forms <i>(required for submittal)</i>	Pass	Fail
Envelope	<input checked="" type="checkbox"/> NRCI-ENV-01-E - For all buildings	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/> NRCA-ENV-02-F- NFRC label verification for fenestration	<input type="checkbox"/>	<input type="checkbox"/>
Mechanical	<input checked="" type="checkbox"/> NRCI-MCH-01-E - For all buildings with Mechanical Systems	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/> NRCA-MCH-02-A- Outdoor Air	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/> NRCA-MCH-03-A – Constant Volume Single Zone HVAC	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-04-H- Air Distribution Duct Leakage	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-05-A- Air Economizer Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-06-A- Demand Control Ventilation	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-07-A – Supply Fan Variable Flow Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-08-A- Valve Leakage Test	<input type="checkbox"/>	<input type="checkbox"/>
	<input checked="" type="checkbox"/> NRCA-MCH-09-A – Supply Water Temp Reset Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-10-A- Hydronic System Variable Flow Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-11-A – Auto Demand Shed Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-12-A- Packaged Direct Expansion Units	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-13-A- Air Handling Units and Zone Terminal Units	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-14-A- Distributed Energy Storage	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-15-A – Thermal Energy Storage	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-16-A- Supply Air Temp Reset Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-17-A – Condensate Water Temp Reset Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-MCH-18-A- Energy Management Controls Systems	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCV-MCH-04-H- Duct Leakage Test	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 6 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

H. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCI/NRCA/NRCV) – Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G. and H. in MCH and LTI Details Sections for Acceptance Tests and forms by equipment.		Confirmed	
Building Component	Compliance Forms (required for submittal)	Pass	Fail
Plumbing	<input checked="" type="checkbox"/> NRCI-PLB-01-E - For all buildings with Plumbing Systems	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-PLB-02-E - required on central systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-PLB-03-E - Single dwelling unit systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-PLB-21-E - HERS verified central systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-PLB-22-E - HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCV-PLB-21-H- HERS verified central systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCV-PLB-22-H - HERS verified single dwelling unit systems in high-rise residential, hotel/motel application.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-STH-01-E - Any solar water heating	<input type="checkbox"/>	<input type="checkbox"/>
Indoor Lighting	<input type="checkbox"/> NRCI-LTI-01-E - For all buildings	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTI-02-E - Lighting control system, or for an Energy Management Control System (EMCS)	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTI-03-E - Line-voltage track lighting integral current limiter, or for a supplementary overcurrent protection panel used to energize only line-voltage track lighting	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTI-04-E - Two interlocked systems serving an auditorium, a convention center, a conference room, or a theater	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTI-05-E - Lighting Control Credit Power Adjustment Factor (PAF)	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTI-06-E - Additional wattage installed in a video conferencing studio	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-LTI-02-A - Occupancy sensors and automatic time switch controls.	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-LTI-03-A - Automatic daylighting controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-LTI-04-A - Demand responsive lighting controls	<input type="checkbox"/>	<input type="checkbox"/>
Outdoor Lighting	<input type="checkbox"/> NRCI-LTO-01-E – Outdoor Lighting	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCI-LTO-02-E- EMCS Lighting Control System	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-LTO-02-A - Outdoor Lighting Control	<input type="checkbox"/>	<input type="checkbox"/>
Sign Lighting	<input type="checkbox"/> NRCI-LTS-01-E – Sign Lighting	<input type="checkbox"/>	<input type="checkbox"/>
Electrical	<input type="checkbox"/> NRCI-ELC-01-E - Electrical Power Distribution	<input type="checkbox"/>	<input type="checkbox"/>
Photovoltaic	<input type="checkbox"/> NRCI-SPV-01-E Photovoltaic Systems	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 7 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

H. CERTIFICATE OF INSTALLATION, CERTIFICATE OF ACCEPTANCE & CERTIFICATE OF VERIFICATION SUMMARY (NRCI/NRCA/NRCV) – Documentation Author to indicate which Certificates must be submitted for the features to be recognized for compliance (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify). See Tables G. and H. in MCH and LTI Details Sections for Acceptance Tests and forms by equipment.		Confirmed	
Building Component	Compliance Forms (required for submittal)	Pass	Fail
Covered Process	<input type="checkbox"/> NRCI-PRC-01-E Refrigerated Warehouse	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-01-F- Compressed Air Systems	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-02-F- Kitchen Exhaust	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-03-F- Garage Exhaust	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-04-F- Refrigerated Warehouse- Evaporator Fan Motor Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-05-F- Refrigerated Warehouse- Evaporative Condenser Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-06-F- Refrigerated Warehouse- Air Cooled Condenser Controls	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-07F- Refrigerated Warehouse- Variable Speed Compressor	<input type="checkbox"/>	<input type="checkbox"/>
	<input type="checkbox"/> NRCA-PRC-08-F- Electrical Resistance Underslab Heating System	<input type="checkbox"/>	<input type="checkbox"/>

I. ENVELOPE GENERAL INFORMATION (See NRCC-PRF-ENV-DETAILS for more information)							
1.	Total Conditioned Floor Area	94,027 ft ²	5.	Number of Floors Above Grade	6	Confirmed	
2.	Total Unconditioned Floor Area	217 ft ²	6.	Number of Floors Below Grade	0	Pass	Fail
3.	Addition Conditioned Floor Area	0 ft ²					
4.	Addition Unconditioned Floor Area	0 ft ²					
7. Opaque Surfaces & Orientation		8. Total Gross Surface Area	9. Total Fenestration Area		10. Window to Wall Ratio		
North Wall		9,972 ft ²	2,212 ft ²		22.2%	<input type="checkbox"/>	<input type="checkbox"/>
East Wall		10,319 ft ²	1,383 ft ²		13.4%	<input type="checkbox"/>	<input type="checkbox"/>
South Wall		9,671 ft ²	1,351 ft ²		14.0%	<input type="checkbox"/>	<input type="checkbox"/>
West Wall		10,720 ft ²	1,751 ft ²		16.3%	<input type="checkbox"/>	<input type="checkbox"/>
Total		40,682 ft ²	6,697 ft ²		16.5%	<input type="checkbox"/>	<input type="checkbox"/>
Roof		17,352 ft ²	0 ft ²		00.0%	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 8 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

J. FENESTRATION ASSEMBLY SUMMARY							§ 110.6		Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.	Pass	Fail
Fenestration Assembly Name / Tag or I.D.	Fenestration Type / Product Type / Frame Type	Certification Method ¹	Assembly Method	Area ft ²	Overall U-factor	Overall SHGC	Overall VT	Status ²		
Double Metal Clear	VerticalFenestration FixedWindow N/A	NFRC Rated	SiteBuilt	6697	0.60	0.30	0.50	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Newly installed fenestration shall have a certified NFRC Label Certificate or use the CEC default tables found in Table 110.6-A and Table 110.6-B. Center of Glass (COG) values are for the glass-only, determined by the manufacturer, and are shown for ease of verification. Site-built fenestration values are calculated per Nonresidential Appendix NA6 and are used in the analysis.

² Status: N - New, A - Altered, E - Existing

Taking compliance credit for fenestration shading devices? (if "Yes", see NRCC-PRF-ENV-DETAILS for more information)	No
--	----

K. OPAQUE SURFACE ASSEMBLY SUMMARY						§ 120.7/ § 140.3		Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	Pass	Fail
Surface Name	Surface Type	Area (ft²)	Framing Type	Cavity R-Value	Continuous R-Value	U-Factor / F-Factor / C-Factor	Status¹		
Slab On Grade6	UndergroundFloor	16178	NA	0	NA	F-Factor: 0.730	N	<input type="checkbox"/>	<input type="checkbox"/>
12 Concrete Wall w/R-138	ExteriorWall	6519	NA	0	13	U-Factor: 0.062	N	<input type="checkbox"/>	<input type="checkbox"/>
12 Concrete Wall11	ExteriorWall	1199	NA	0	NA	U-Factor: 0.315	N	<input type="checkbox"/>	<input type="checkbox"/>
R-19 Wall32	ExteriorWall	33355	Wood	19	NA	U-Factor: 0.072	N	<input type="checkbox"/>	<input type="checkbox"/>
R-13 Wall63	InteriorWall	250	Wood	13	NA	U-Factor: 0.095	N	<input type="checkbox"/>	<input type="checkbox"/>
R-0 Floor No Crawlspace120	InteriorFloor	78022	NA	0	NA	U-Factor: 0.183	N	<input type="checkbox"/>	<input type="checkbox"/>
R-30 Roof Cathedral143	Roof	2946	Wood	30	NA	U-Factor: 0.034	N	<input type="checkbox"/>	<input type="checkbox"/>
R-30 Roof Attic269	Roof	14406	Wood	30	NA	U-Factor: 0.038	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Status: N - New, A - Altered, E - Existing

L. ROOFING PRODUCT SUMMARY							§ 140.3	Confirmed	
1.	2.	3.	4.	5.	6.	7.	Pass	Fail	
Product Type	Product Density (lb/ft²)	Aged Solar Reflectance	Thermal Emittance	SRI	Cool Roof Credit	Roofing Product Description			
R-30 Roof Cathedral143	4.65104	0.08	0.75	NA	No	NA	<input type="checkbox"/>	<input type="checkbox"/>	
R-30 Roof Attic269	4.65104	0.08	0.75	NA	No	NA	<input type="checkbox"/>	<input type="checkbox"/>	

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 9 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

M. HVAC SYSTEM SUMMARY (see NRCC-PRF-MCH-DETAILS for more information)										§ 110.1 / § 110.2			
Dry System Equipment ¹ (Fan & Economizer info included below in Table N)												Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.		10.	11.	Pass	Fail
Equip Name	Equip Type	System Type (Simple ² or Complex ³)	Qty	Total Heating Output (kBtu/h)	Supp Heat Source (Y/N)	Supp Heat Output (kBtuh)	Total Cooling Output (kBtu/h)	Efficiency		Acceptance Testing Required? (Y/N) ⁴	Status ⁵		
								Cooling	Heating				
DOAS	SZAC (Packaged3Phase)	Simple	1	200	No	0	190	EER-12.2	ThrmIEff- 80.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-18 6th Office 2	SZHP (Split3Phase)	Simple	1	14	No	0	12	SEER-14.0 / EER-12.2	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-19 6th Office 3	SZHP (Split3Phase)	Simple	1	14	No	0	12	SEER-14.0 / EER-12.2	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-20 6th Open Office	SZHP (Split3Phase)	Simple	1	20	No	0	21	SEER-13.0 / EER-11.5	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-21 6th Office 1/Temple	SZHP (Split3Phase)	Simple	1	15	No	0	16	SEER-13.0 / EER-11.4	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-1 Lobby	SZHP (Split3Phase)	Simple	1	39	No	0	42	SEER-13.0 / EER-11.5	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-2 Breakfast 1	SZHP (Split3Phase)	Simple	1	80	No	0	69	EER-12.2	COP-3.4	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-3 Food Prep	SZHP (Split3Phase)	Simple	1	14	No	0	12	SEER-14.0 / EER-12.2	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-4 Corridor 2	SZHP (Split3Phase)	Simple	1	14	No	0	12	SEER-14.0 / EER-12.2	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-5 Fitness	SZHP (Split3Phase)	Simple	1	20	No	0	21	SEER-13.0 / EER-11.5	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-6 Game Room	SZHP (Split3Phase)	Simple	1	20	No	0	21	SEER-13.0 / EER-11.5	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-7 Breakfast 2	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-8 Meeting Room 1	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-9 Meeting Room 2	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 10 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

M. HVAC SYSTEM SUMMARY (see NRCC-PRF-MCH-DETAILS for more information)										§ 110.1 / § 110.2			
Dry System Equipment ¹ (Fan & Economizer info included below in Table N)												Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.		10.	11.	Pass	Fail
Equip Name	Equip Type	System Type (Simple ² or Complex ³)	Qty	Total Heating Output (kBtu/h)	Supp Heat Source (Y/N)	Supp Heat Output (kBtuh)	Total Cooling Output (kBtu/h)	Efficiency		Acceptance Testing Required? (Y/N) ⁴	Status ⁵		
								Cooling	Heating				
FC-10 Corridor/RR	SZHP (Split3Phase)	Simple	1	20	No	0	21	SEER-13.0 / EER-11.5	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-11 Laundry	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-12 Offices	SZHP (Split3Phase)	Simple	1	34	No	0	29	SEER-14.0 / EER-11.6	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-13 Offices	SZHP (Split3Phase)	Simple	1	15	No	0	16	SEER-13.0 / EER-11.4	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-14 2nd Corridor	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-15 3rd Corridor	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-16 4th Corridor	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-17 5th Corridor	SZHP (Split3Phase)	Simple	1	40	No	0	35	SEER-13.0 / EER-12.3	HSPF-11.7	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
FC-23 PBX	SZHP (Split3Phase)	Simple	1	12	No	0	14	SEER-13.0 / EER-11.4	HSPF-12.0	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #101	PTHP (Split3Phase)	Simple	2	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #105	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #139	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #140	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #141	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #142	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
Suite #143	PTHP (Split3Phase)	Simple	1	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 11 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

M. HVAC SYSTEM SUMMARY (see NRCC-PRF-MCH-DETAILS for more information)										§ 110.1 / § 110.2			
Dry System Equipment ¹ (Fan & Economizer info included below in Table N)												Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.		10.	11.	Pass	Fail
Equip Name	Equip Type	System Type (Simple ² or Complex ³)	Qty	Total Heating Output (kBtu/h)	Supp Heat Source (Y/N)	Supp Heat Output (kBtuh)	Total Cooling Output (kBtu/h)	Efficiency		Acceptance Testing Required? (Y/N) ⁴	Status ⁵		
								Cooling	Heating				
2nd - Guest Rooms	PTHP (Split3Phase)	Simple	38	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
3rd - Guest Rooms	PTHP (Split3Phase)	Simple	38	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
4th - Guest Rooms	PTHP (Split3Phase)	Simple	38	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>
5th - Guest Rooms	PTHP (Split3Phase)	Simple	38	6	Yes	8	6	EER-11.9	COP-3.3	Yes	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Dry System Equipment includes furnaces, air handling units, heat pumps, etc.

² Simple Systems must complete NRCC-CXR-03-E commissioning design review form

³ Complex Systems must complete NRCC-CXR-04-E commissioning design review form

⁴ A summary of which acceptance tests are applicable is provided in NRCC-PRF-MCH-DETAILS

⁵ Status: N - New, A - Altered, E - Existing

Wet System Equipment ¹								Pumps					Confirmed	
12.	13.	14.	15.	16.	17.	18.	19.	20.	21.	22.	23.	24.	Pass	Fail
Equip Name	Equip Type	Qty	Vol (gal)	Rated Capacity (kBtu/h)	Efficiency	Standby Loss	Tank Ext. R Value	Qty	GPM	HP	VSD (Y/N)	Status ²		
Intellihot iQ7511	Instantaneous	2	1	751	ThrmI. Eff.: 0.940	0.0000	NA	NA	NA	NA	No	N	<input type="checkbox"/>	<input type="checkbox"/>
Intellihot iQ7511 2	Instantaneous	22	1	751	ThrmI. Eff.: 0.940	NA	0.0	NA	NA	0 (kW)	NA	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Wet System Equipment includes boilers, chillers, cooling towers, water heaters, etc.

² Status: N - New, A - Altered, E - Existing

Discrepancy between modeled and designed equipment sizing? (if "Yes", see Table F. "Additional Remarks" for an explanation)	No
---	----

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 12 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

N. ECONOMIZER & FAN SYSTEMS SUMMARY ¹													\$ 140.4		Confirmed	
1.	2.	3.					4.					5.	Pass	Fail		
Equip Name	Outside Air	Supply Fan					Return Fan					Economizer Type (if present)				
	CFM	CFM	HP	BHP	TSP (inch WC)	Control	CFM	HP	BHP	TSP (inch WC)	Control					
DOAS	5146	5460	4.100	4.100	2.86	ConstantVolume	NA	NA	NA	NA	NA	NoEconomizer	<input type="checkbox"/>	<input type="checkbox"/>		
FC-18 6th Office 2	55	370	0.072	0.072	0.62	ConstantVolume	NA	NA	NA	NA	NA	NoEconomizer	<input type="checkbox"/>	<input type="checkbox"/>		
FC-19 6th Office 3	55	370	0.072	0.072	0.62	ConstantVolume	NA	NA	NA	NA	NA	NoEconomizer	<input type="checkbox"/>	<input type="checkbox"/>		
FC-20 6th Open Office	189	800	0.136	0.136	0.54	ConstantVolume	NA	NA	NA	NA	NA	NoEconomizer	<input type="checkbox"/>	<input type="checkbox"/>		
FC-21 6th Office 1/Temple	146	600	0.088	0.088	0.47	ConstantVolume	NA	NA	NA	NA	NA	NoEconomizer	<input type="checkbox"/>	<input type="checkbox"/>		
FC-1 Lobby	0	1400	0.272	0.272	0.62	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-2 Breakfast 1	0	2160	0.656	0.656	0.96	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-3 Food Prep	0	370	0.072	0.072	0.62	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-4 Corridor 2	0	370	0.072	0.072	0.62	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-5 Fitness	0	800	0.136	0.136	0.54	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-6 Game Room	0	800	0.136	0.136	0.54	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-7 Breakfast 2	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-8 Meeting Room 1	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-9 Meeting Room 2	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-10 Corridor/RR	0	800	0.136	0.136	0.54	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-11 Laundry	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-12 Offices	0	880	0.136	0.136	0.49	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-13 Offices	0	600	0.088	0.088	0.47	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 13 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

N. ECONOMIZER & FAN SYSTEMS SUMMARY ¹													\$ 140.4		Confirmed	
1.	2.	3.					4.					5.	Pass	Fail		
Equip Name	Outside Air	Supply Fan					Return Fan					Economizer Type (if present)				
	CFM	CFM	HP	BHP	TSP (inch WC)	Control	CFM	HP	BHP	TSP (inch WC)	Control					
FC-14 2nd Corridor	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-15 3rd Corridor	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-16 4th Corridor	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-17 5th Corridor	0	1160	0.192	0.192	0.53	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
FC-23 PBX	0	425	0.024	0.024	0.18	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #101	46	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #105	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #139	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #140	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #141	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #142	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
Suite #143	30	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
2nd - Guest Rooms	64	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
3rd - Guest Rooms	64	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
4th - Guest Rooms	64	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		
5th - Guest Rooms	64	240	0.001	0.001	0.01	ConstantVolume	NA	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>		

¹ Mechanical ventilation calculations and exhaust fans are included in the NRCC-PRF-MCH-DETAILS section

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 14 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

O. EQUIPMENT CONTROLS			§ 120.2	Confirmed	
1.	2.	3.	Pass	Fail	
Equip Name	Equip Type	Controls			
DOAS	SZAC	No DCV Controls No Economizer No Supply Air Temp. Control No Optimum Start No Evaporative Cooler	<input type="checkbox"/>	<input type="checkbox"/>	
FC-18 6th Office 2	SZHP	No DCV Controls No Economizer No Supply Air Temp. Control No Optimum Start No Evaporative Cooler	<input type="checkbox"/>	<input type="checkbox"/>	
FC-19 6th Office 3	SZHP	No DCV Controls No Economizer No Supply Air Temp. Control No Optimum Start No Evaporative Cooler	<input type="checkbox"/>	<input type="checkbox"/>	
FC-20 6th Open Office	SZHP	No DCV Controls No Economizer No Supply Air Temp. Control No Optimum Start No Evaporative Cooler	<input type="checkbox"/>	<input type="checkbox"/>	
FC-21 6th Office 1/Temple	SZHP	No DCV Controls No Economizer No Supply Air Temp. Control No Optimum Start No Evaporative Cooler	<input type="checkbox"/>	<input type="checkbox"/>	
Gateway Hotel2 - SHW	Service Hot Water, Primary Only	Fixed Temperature Control, No DDC	<input type="checkbox"/>	<input type="checkbox"/>	

P. SYSTEM DISTRIBUTION SUMMARY						§ 120.4/ § 140.4(I)	
		Dry System Distribution				Confirmed	
1.	2.	3.	4.	5.		Pass	Fail
Equip Name	Equip Type	Duct Leakage and Sealing Required per 140.4(I)	Duct Leakage will be verified per NA1 and NA2	Ducts			
				Insulation R-Value	Location		
DOAS	SZAC	No	No	6	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 15 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

P. SYSTEM DISTRIBUTION SUMMARY					§ 120.4/ § 140.4(I)		
		Dry System Distribution				Confirmed	
1.	2.	3.	4.	5.		Pass	Fail
Equip Name	Equip Type	Duct Leakage and Sealing Required per 140.4(I)	Duct Leakage will be verified per NA1 and NA2	Ducts			
				Insulation R-Value	Location		
FC-18 6th Office 2	SZHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
FC-19 6th Office 3	SZHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
FC-20 6th Open Office	SZHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
FC-21 6th Office 1/Temple	SZHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
FC-1 Lobby	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-2 Breakfast 1	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-3 Food Prep	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-4 Corridor 2	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-5 Fitness	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-6 Game Room	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-7 Breakfast 2	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-8 Meeting Room 1	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-9 Meeting Room 2	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-10 Corridor/RR	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-11 Laundry	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-12 Offices	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-13 Offices	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-14 2nd Corridor	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-15 3rd Corridor	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-16 4th Corridor	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-17 5th Corridor	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
FC-23 PBX	SZHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
Suite #101	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
Suite #105	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 16 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

P. SYSTEM DISTRIBUTION SUMMARY						§ 120.4/ § 140.4(I)	
		Dry System Distribution				Confirmed	
1.	2.	3.	4.	5.		Pass	Fail
Equip Name	Equip Type	Duct Leakage and Sealing Required per 140.4(I)	Duct Leakage will be verified per NA1 and NA2	Ducts			
				Insulation R-Value	Location		
Suite #139	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
Suite #140	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
Suite #141	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
Suite #142	PTHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
Suite #143	PTHP	No	No	8	Conditioned	<input type="checkbox"/>	<input type="checkbox"/>
2nd - Guest Rooms	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
3rd - Guest Rooms	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
4th - Guest Rooms	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>
5th - Guest Rooms	PTHP	No	No	8	None	<input type="checkbox"/>	<input type="checkbox"/>

Does the Project Include Zonal Systems? (if "Yes", see NRCC-PRF-MCH-DETAILS for system information)	Yes
Does the Project Include a Solar Hot Water System? (if "Yes", see NRCC-PRF-MCH-DETAILS for system information)	No
Multifamily or Hotel/ Motel Occupancy? (if "Yes", see NRCC-PRF-MCH-DETAILS for DHW system information)	Yes

Q. INDOOR CONDITIONED LIGHTING GENERAL INFO (see NRCC-PRF-LTI-DETAILS for more info)
This Section Does Not Apply

R. INDOOR CONDITIONED LIGHTING SCHEDULE (Adapted from NRCC-LTI-01-E) ¹	§ 130.0
This Section Does Not Apply	

¹If lighting power densities were used in the compliance model Building Departments will need to check prescriptive forms for Luminaire Schedule details.

S1. COVERED PROCESS SUMMARY – ENCLOSED PARKING GARAGES	§ 140.9
This Section Does Not Apply	

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 17 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

S2. COVERED PROCESS SUMMARY – COMMERCIAL KITCHENS					§ 140.9	
Space Name	Exhaust Hood Style	Exhaust Hood Duty	Exhaust Length (ft)	Exhaust Flow Rate (cfm)	Confirmed	
					Pass	Fail
S-3-Food Prep		Light			<input type="checkbox"/>	<input type="checkbox"/>
		Light			<input type="checkbox"/>	<input type="checkbox"/>
		Light			<input type="checkbox"/>	<input type="checkbox"/>
		Light			<input type="checkbox"/>	<input type="checkbox"/>
		Light			<input type="checkbox"/>	<input type="checkbox"/>

S3. COVERED PROCESS SUMMARY – COMPUTER ROOMS	§ 140.9
This Section Does Not Apply	

S4. COVERED PROCESS SUMMARY – LABORATORY EXHAUSTS	§ 140.9
This Section Does Not Apply	

T. UNMET LOAD HOURS				
Thermal Zone Name	Cooling Unmet Load Hour Limit for Thermal Zone	Proposed Cooling Unmet Load Hours	Heating Unmet Load Hour Limit for Thermal Zone	Proposed Heating Unmet Load Hours
24-Conference	150	1874.25	150	0

U. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Space Heating	0.0	54.5	--	695.5	144.2	551.3
Space Cooling	11.9	16.3	-4.4	--	--	--
Indoor Fans	73.8	42.8	31.0	--	--	--
Heat Rejection	0.1	--	--	--	--	--
Pumps & Misc.	6.7	--	--	--	--	--
Domestic Hot Water	--	--	--	218.9	177.1	41.8
Indoor Lighting	157.0	157.0	0.0	--	--	--
COMPLIANCE TOTAL	249.5	270.6	-21.1	914.4	321.3	593.1


Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 18 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

U. ENERGY USE SUMMARY						
Energy Component	Standard Design Site (MWh)	Proposed Design Site (MWh)	Margin (MWh)	Standard Design Site (MBtu)	Proposed Design Site (MBtu)	Margin (MBtu)
Receptacle	162.6	162.6	0.0	2.2	2.2	0.0
Process	4.0	4.0	0.0	--	--	--
Other Ltg	--	--	--	--	--	--
TOTAL	416.1	437.2	-21.1	916.6	323.5	593.1

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 19 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

DOCUMENTATION AUTHOR'S DECLARATION STATEMENT	§ 10-103
---	-----------------


I certify that this Certificate of Compliance documentation is accurate and complete.

Documentation Author Name: Tyler D. Reynolds	Signature: 
Company: JVA Mechanical Engineering	
Address: 510 State Street, Suite 285	Signature Date: Sat, Oct 14, 2017
City/State/Zip: Santa Barbara CA 93101	CEA Identification (If applicable):
Phone: (805) 543-3190	


RESPONSIBLE PERSON'S DECLARATION STATEMENT

I certify the following under penalty of perjury, under the laws of the State of California:

1	I hereby affirm that I am eligible under the provisions of Division 3 of the Business and Professions Code to sign this document as the person responsible for its preparation; and that I am licensed in the State of California as a civil engineer, mechanical engineer, electrical engineer, or I am a licensed architect.
2	I affirm that I am eligible under the provisions of Division 3 of the Business and Professions Code by section 5537.2 or 6737.3 to sign this document as the person responsible for its preparation; and that I am a licensed contractor performing this work.
3	I affirm that I am eligible under Division 3 of the Business and Professions Code to sign this document because it pertains to a structure or type of work described as exempt pursuant to Business and Professions Code Sections 5537, 5538 and 6737.1.

Responsible Envelope Designer Name: Thomas E. Jess	Signature: 
Company: Arris Studio Architects	
Address: 1306 Johnson Avenue	Date Signed: Sat, Oct 14, 2017
City/State/Zip: San Luis Obispo CA 93401	Declaration Statement Type: 1
Phone: (805) 547-2240	Title: Architect License #: C27608

Responsible Lighting Designer Name:	Signature: NOT IN SCOPE
Company:	
Address:	Date Signed:
City/State/Zip:	Declaration Statement Type:
Phone:	Title: License #:

Responsible Mechanical Designer Name: James L. Van De Vanter, P.E.	Signature: 
Company: JVA Mechanical Engineering	
Address: 510 State Street, Suite 285	Date Signed: Sat, Oct 14, 2017
City/State/Zip: Santa Barbara CA 93101	Declaration Statement Type: 1
Phone: (805) 543-3190	Title: Mechanical Engineer License #: M31205

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 20 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

NRCC-PRF-ENV-DETAILS -SECTION START-

A. OPAQUE SURFACE ASSEMBLY DETAILS				Confirmed	
1.	2.	3.	4.	Pass	Fail
Surface Name	Surface Type	Description of Assembly Layers	Notes		
Slab On Grade6	UndergroundFloor	Slab Type = UnheatedSlabOnGrade Insulation Orientation = None Insulation R-Value = R0		<input type="checkbox"/>	<input type="checkbox"/>
12 Concrete Wall w/R-138	ExteriorWall	Concrete - Solid Grout - 105 lb/ft3 - 12 in. Glass fiber batt - 3 1/2 in. R13 (CEC Default) Air - Cavity - Wall Roof Ceiling - 4 in. or more		<input type="checkbox"/>	<input type="checkbox"/>
12 Concrete Wall11	ExteriorWall	Concrete - Solid Grout - 105 lb/ft3 - 12 in. Air - Cavity - Wall Roof Ceiling - 4 in. or more		<input type="checkbox"/>	<input type="checkbox"/>
R-19 Wall32	ExteriorWall	Stucco - 7/8 in. Vapor permeable felt - 1/8 in. Wood framed wall, 16in. OC, 5.5in., R-19 Gypsum Board - 1/2 in.		<input type="checkbox"/>	<input type="checkbox"/>
R-13 Wall63	InteriorWall	Stucco - 7/8 in. Vapor permeable felt - 1/8 in. Wood framed wall, 16in. OC, 3.5in., R-13 Gypsum Board - 1/2 in.		<input type="checkbox"/>	<input type="checkbox"/>
R-0 Floor No Crawlspace120	InteriorFloor	Air - Cavity - Wall Roof Ceiling - 4 in. or more Plywood - 1/2 in. Carpet - 3/4 in.		<input type="checkbox"/>	<input type="checkbox"/>
R-30 Roof Cathedral143	Roof	Asphalt shingles - 1/4 in. Vapor permeable felt - 1/8 in. Plywood - 1/2 in. Air - Cavity - Wall Roof Ceiling - 4 in. or more Wood framed roof, 16in. OC, 11.25in., R-30 Gypsum Board - 1/2 in.		<input type="checkbox"/>	<input type="checkbox"/>
R-30 Roof Attic269	Roof	Asphalt shingles - 1/4 in. Vapor permeable felt - 1/8 in. Plywood - 1/2 in. Air - Cavity - Wall Roof Ceiling - 4 in. or more Wood framed roof, 24in. OC, 3.5in., R-30 Gypsum Board - 1/2 in.		<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 21 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

B. OVERHANG DETAILS (Adapted from NRCC-ENV-02-E)

This Section Does Not Apply

C. OPAQUE DOOR SUMMARY							Confirmed	
1.	2.	3.	4.	5.	6.	7.	Pass	Fail
Opaque Door Assembly Name / Tag or I.D.	Door Type	Certification Method	Operation	Area	Overall U-factor	Status ¹		
Hollow Metal Door171	MetalUninsulatedDoubleLayerDoor	DefaultPerformance	Swinging	21	0.700	N	<input type="checkbox"/>	<input type="checkbox"/>

¹ Status: N - New, A - Altered, E - Existing

NRCC-PRF-MCH-DETAILS -SECTION START-

A. MECHANICAL VENTILATION AND REHEAT (Adapted from 2016-NRCC-MCH-03-E)																		Confirmed	
1. DESIGN AIR FLOWS								2. VENTILATION (§ 120.1)										Pass	Fail
CONDITIONED ZONE NAME	HEATING/COOLING SYSTEM ID	DESIGN PRIMARY AIR FLOW (CFM)	DESIGN PRIMARY MINIMUM AIR FLOW (CFM)	MINIMUM PRIMARY AIR FLOW FRACTION	MAXIMUM HEATING AIR FLOW (CFM)	MAXIMUM HEATING AIR FLOW FRACTION	DDC CONTROL (Y/N)	VENT SYSTEM ID	CONDITIONED AREA (ft2)	MIN. VENT PER AREA (CFM/ft2)	DESIGN NUM. OF PEOPLE	MIN. VENT PER PERSON (CFM/person)	REQ'D VENT AIR FLOW (CFM)	DESIGN VENT AIR FLOW (CFM)	TRANSFER AIRFLOW (CFM)	DCV (Y/N)	Operable Window Interlock § 140.4(n) (Y/N)		
1-FC-1 Lobby	FC-1 Lobby	1,400	NA	NA	NA	NA	N	DOAS	1,850	NA	9	30.0	278	278	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
2-Breakfast 1	FC-2 Breakfast 1	2,160	NA	NA	NA	NA	N	DOAS	1,925	NA	64	15.0	963	963	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
3-Food Prep	FC-3 Food Prep	370	NA	NA	NA	NA	N	DOAS	453	NA	1	60.0	68	68	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
4-Corridor 2	FC-4 Corridor 2	370	NA	NA	NA	NA	N	DOAS	695	NA	3	30.0	104	104	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
5-Fitness	FC-5 Fitness	800	NA	NA	NA	NA	N	DOAS	630	NA	6	15.0	95	95	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 22 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

A. MECHANICAL VENTILATION AND REHEAT (Adapted from 2016-NRCC-MCH-03-E)																		Confirmed	
1. DESIGN AIR FLOWS								2. VENTILATION (§ 120.1)										Pass	Fail
CONDITIONED ZONE NAME	HEATING/COOLING SYSTEM ID	DESIGN PRIMARY AIR FLOW (CFM)	DESIGN PRIMARY MINIMUM AIR FLOW (CFM)	MINIMUM PRIMARY AIR FLOW FRACTION	MAXIMUM HEATING AIR FLOW (CFM)	MAXIMUM HEATING AIR FLOW FRACTION	DDC CONTROL (Y/N)	VENT SYSTEM ID	CONDITIONED AREA (ft2)	MIN. VENT PER AREA (CFM/ft2)	DESIGN NUM. OF PEOPLE (CFM/person)	MIN. VENT PER PERSON (CFM/person)	REQ'D VENT AIR FLOW (CFM)	DESIGN VENT AIR FLOW (CFM)	TRANSFER AIRFLOW (CFM)	DCV (Y/N)	Operable Window Interlock § 140.4(n) (Y/N)		
6-Game Room	FC-6 Game Room	800	NA	NA	NA	NA	N	DOAS	368	NA	12	15.0	184	184	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
7-Breakfast 2	FC-7 Breakfast 2	1,160	NA	NA	NA	NA	N	DOAS	886	NA	30	15.0	443	443	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
8-Meeting Room 1	FC-8 Meeting Room 1	1,160	NA	NA	NA	NA	N	DOAS	662	NA	22	15.0	331	331	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
10-Meeting Room 2	FC-9 Meeting Room 2	1,160	NA	NA	NA	NA	N	DOAS	698	NA	23	15.0	349	349	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
11-Corridor/RR	FC-10 Corridor/R R	800	NA	NA	NA	NA	N	DOAS	1,688	NA	8	30.0	253	253	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
12-Laundry	FC-11 Laundry	1,160	NA	NA	NA	NA	N	DOAS	1,210	NA	6	30.0	182	182	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
13-Offices	FC-12 Offices	880	NA	NA	NA	NA	N	DOAS	1,075	NA	5	30.0	161	161	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
14-Offices	FC-13 Offices	600	NA	NA	NA	NA	N	DOAS	664	NA	3	30.0	100	100	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
15-Corridor	FC-14 2nd Corridor	1,160	NA	NA	NA	NA	N	DOAS	2,689	NA	13	30.0	403	403	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
16-Corridor	FC-15 3rd Corridor	1,160	NA	NA	NA	NA	N	DOAS	2,689	NA	13	30.0	403	403	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 23 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

A. MECHANICAL VENTILATION AND REHEAT (Adapted from 2016-NRCC-MCH-03-E)																		Confirmed	
1. DESIGN AIR FLOWS								2. VENTILATION (§ 120.1)										Pass	Fail
CONDITIONED ZONE NAME	HEATING/COOLING SYSTEM ID	DESIGN PRIMARY AIR FLOW (CFM)	DESIGN PRIMARY MINIMUM AIR FLOW (CFM)	MINIMUM PRIMARY AIR FLOW FRACTION	MAXIMUM HEATING AIR FLOW (CFM)	MAXIMUM HEATING AIR FLOW FRACTION	DDC CONTROL (Y/N)	VENT SYSTEM ID	CONDITIONED AREA (ft2)	MIN. VENT PER AREA (CFM/ft2)	DESIGN NUM. OF PEOPLE	MIN. VENT PER PERSON (CFM/person)	REQ'D VENT AIR FLOW (CFM)	DESIGN VENT AIR FLOW (CFM)	TRANSFER AIRFLOW (CFM)	DCV (Y/N)	Operable Window Interlock § 140.4(n) (Y/N)		
17-Corridor	FC-16 4th Corridor	1,160	NA	NA	NA	NA	N	DOAS	2,689	NA	13	30.0	403	403	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
18-Corridor	FC-17 5th Corridor	1,160	NA	NA	NA	NA	N	DOAS	2,689	NA	13	30.0	403	403	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
19-Office 2	FC-18 6th Office 2	370	NA	NA	NA	NA	N	FC-18 6th Office 2	364	NA	2	30.0	55	55	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
20-Office 3	FC-19 6th Office 3	370	NA	NA	NA	NA	N	FC-19 6th Office 3	366	NA	2	30.0	55	55	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
21-Open Office	FC-20 6th Open Office	800	NA	NA	NA	NA	N	FC-20 6th Open Office	1,262	NA	6	30.0	189	189	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
22-Office 1	FC-21 6th Office 1/Temple	226	NA	NA	NA	NA	N	FC-21 6th Office 1/Temple	187	NA	1	30.0	28	28	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
23-Temple Room	FC-21 6th Office 1/Temple	127	NA	NA	NA	NA	N	FC-21 6th Office 1/Temple	105	NA	1	30.0	16	16	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
24-Conference	FC-21 6th Office 1/Temple	247	NA	NA	NA	NA	N	FC-21 6th Office 1/Temple	205	NA	7	15.0	103	103	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
25-PBX	FC-23 PBX	425	NA	NA	NA	NA	N	DOAS	154	NA	0	100.0	23	23	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
26-#101	Suite #101	NA	NA	NA	NA	NA	N	Suite #101	617	NA	2	60.0	93	93	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
27-#105	Suite #105	NA	NA	NA	NA	NA	N	Suite #105	496	NA	1	24.2	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
28-#139	Suite #139	NA	NA	NA	NA	NA	N	Suite #139	359	NA	1	33.4	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 24 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

A. MECHANICAL VENTILATION AND REHEAT (Adapted from 2016-NRCC-MCH-03-E)																		Confirmed	
1. DESIGN AIR FLOWS								2. VENTILATION (§ 120.1)										Pass	Fail
CONDITIONED ZONE NAME	HEATING/COOLING SYSTEM ID	DESIGN PRIMARY AIR FLOW (CFM)	DESIGN PRIMARY MINIMUM AIR FLOW (CFM)	MINIMUM PRIMARY AIR FLOW FRACTION	MAXIMUM HEATING AIR FLOW (CFM)	MAXIMUM HEATING AIR FLOW FRACTION	DDC CONTROL (Y/N)	VENT SYSTEM ID	CONDITIONED AREA (ft2)	MIN. VENT PER AREA (CFM/ft2)	DESIGN NUM. OF PEOPLE (CFM/person)	MIN. VENT PER PERSON (CFM/person)	REQ'D VENT AIR FLOW (CFM)	DESIGN VENT AIR FLOW (CFM)	TRANSFER AIRFLOW (CFM)	DCV (Y/N)	Operable Window Interlock § 140.4(n) (Y/N)		
29-#140	Suite #140	NA	NA	NA	NA	NA	N	Suite #140	363	NA	1	33.1	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
30-#141	Suite #141	NA	NA	NA	NA	NA	N	Suite #141	395	NA	1	30.4	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
31-#142	Suite #142	NA	NA	NA	NA	NA	N	Suite #142	369	NA	1	32.5	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
32-#143	Suite #143	NA	NA	NA	NA	NA	N	Suite #143	401	NA	1	29.9	30	30	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
33-Guest Rm - 2nd	2nd - Guest Rooms	NA	NA	NA	NA	NA	N	2nd - Guest Rooms	16,206	NA	41	60.0	2,431	2,431	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
34-Guest Rm - 3rd	3rd - Guest Rooms	NA	NA	NA	NA	NA	N	3rd - Guest Rooms	16,206	NA	41	60.0	2,431	2,431	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
35-Guest Rm - 4th	4th - Guest Rooms	NA	NA	NA	NA	NA	N	4th - Guest Rooms	16,206	NA	41	60.0	2,431	2,431	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
36-Guest Rm - 5th	5th - Guest Rooms	NA	NA	NA	NA	NA	N	5th - Guest Rooms	16,206	NA	41	60.0	2,431	2,431	NA	N	NA	<input type="checkbox"/>	<input type="checkbox"/>
								TOTAL	94,244		NA		NA	NA	NA			<input type="checkbox"/>	<input type="checkbox"/>

B. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY													§ 140.4	
1.	2.	3.	4.		5.	6.	7.			8.			Confirmed	
System ID	System Type	Qty	Rated Capacity (kBtuh)		Economizer	Zone Name	Airflow (cfm)			Fan			Pass	Fail
			Heating	Cooling			Design	Min.	Min. Ratio	BHP	Cycles	ECM Motor		
FC-1 Lobby	PTHP	1	39.00	42.00	No	1-FC-1 Lobby	1400	NA	NA	0.272	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-2 Breakfast 1	PTHP	1	80.00	69.00	No	2-Breakfast 1	2160	NA	NA	0.656	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 25 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

B. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY													\$ 140.4	
1.	2.	3.	4.		5.	6.	7.			8.			Confirmed	
System ID	System Type	Qty	Rated Capacity (kBtuh)		Economizer	Zone Name	Airflow (cfm)			Fan			Pass	Fail
			Heating	Cooling			Design	Min.	Min. Ratio	BHP	Cycles	ECM Motor		
FC-3 Food Prep	PTHP	1	14.00	12.00	No	3-Food Prep	370	NA	NA	0.072	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-4 Corridor 2	PTHP	1	14.00	12.00	No	4-Corridor 2	370	NA	NA	0.072	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-5 Fitness	PTHP	1	20.00	21.00	No	5-Fitness	800	NA	NA	0.136	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-6 Game Room	PTHP	1	20.00	21.00	No	6-Game Room	800	NA	NA	0.136	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-7 Breakfast 2	PTHP	1	40.00	35.00	No	7-Breakfast 2	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-8 Meeting Room 1	PTHP	1	40.00	35.00	No	8-Meeting Room 1	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-9 Meeting Room 2	PTHP	1	40.00	35.00	No	10-Meeting Room 2	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-10 Corridor/RR	PTHP	1	20.00	21.00	No	11-Corridor/RR	800	NA	NA	0.136	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-11 Laundry	PTHP	1	40.00	35.00	No	12-Laundry	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-12 Offices	PTHP	1	34.00	29.00	No	13-Offices	880	NA	NA	0.136	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-13 Offices	PTHP	1	15.00	16.00	No	14-Offices	600	NA	NA	0.088	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-14 2nd Corridor	PTHP	1	40.00	35.00	No	15-Corridor	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-15 3rd Corridor	PTHP	1	40.00	35.00	No	16-Corridor	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-16 4th Corridor	PTHP	1	40.00	35.00	No	17-Corridor	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-17 5th Corridor	PTHP	1	40.00	35.00	No	18-Corridor	1160	NA	NA	0.192	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
FC-23 PBX	PTHP	1	12.00	14.00	No	25-PBX	425	NA	NA	0.024	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #101	PTHP	2	6.00	6.00	No	26-#101	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #105	PTHP	1	6.00	6.00	No	27-#105	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #139	PTHP	1	6.00	6.00	No	28-#139	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #140	PTHP	1	6.00	6.00	No	29-#140	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #141	PTHP	1	6.00	6.00	No	30-#141	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #142	PTHP	1	6.00	6.00	No	31-#142	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suite #143	PTHP	1	6.00	6.00	No	32-#143	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2nd - Guest Rooms	PTHP	38	6.00	6.00	No	33-Guest Rm - 2nd	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 26 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

B. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY													\$ 140.4	
1.	2.	3.	4.		5.	6.	7.			8.			Confirmed	
System ID	System Type	Qty	Rated Capacity (kBtuh)		Economizer	Zone Name	Airflow (cfm)			Fan			Pass	Fail
			Heating	Cooling			Design	Min.	Min. Ratio	BHP	Cycles	ECM Motor		
3rd - Guest Rooms	PTHP	38	6.00	6.00	No	34-Guest Rm - 3rd	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4th - Guest Rooms	PTHP	38	6.00	6.00	No	35-Guest Rm - 4th	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5th - Guest Rooms	PTHP	38	6.00	6.00	No	36-Guest Rm - 5th	240	NA	NA	0.001	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
25-PBX-Trm	Uncontrolled	1	NA	NA	NA	25-PBX	425	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
18-Corridor-Trm	Uncontrolled	1	NA	NA	NA	18-Corridor	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
17-Corridor-Trm	Uncontrolled	1	NA	NA	NA	17-Corridor	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
16-Corridor-Trm	Uncontrolled	1	NA	NA	NA	16-Corridor	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
15-Corridor-Trm	Uncontrolled	1	NA	NA	NA	15-Corridor	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
14-Offices-Trm	Uncontrolled	1	NA	NA	NA	14-Offices	600	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
13-Offices-Trm	Uncontrolled	1	NA	NA	NA	13-Offices	880	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
12-Laundry-Trm	Uncontrolled	1	NA	NA	NA	12-Laundry	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
11-Corridor/RR-Trm	Uncontrolled	1	NA	NA	NA	11-Corridor/RR	800	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
10-Meeting Room 2-Trm	Uncontrolled	1	NA	NA	NA	10-Meeting Room 2	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8-Meeting Room 1-Trm	Uncontrolled	1	NA	NA	NA	8-Meeting Room 1	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
7-Breakfast 2-Trm	Uncontrolled	1	NA	NA	NA	7-Breakfast 2	1160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
6-Game Room-Trm	Uncontrolled	1	NA	NA	NA	6-Game Room	800	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
5-Fitness-Trm	Uncontrolled	1	NA	NA	NA	5-Fitness	800	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
4-Corridor 2-Trm	Uncontrolled	1	NA	NA	NA	4-Corridor 2	370	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
3-Food Prep-Trm	Uncontrolled	1	NA	NA	NA	3-Food Prep	370	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2-Breakfast 1-Trm	Uncontrolled	1	NA	NA	NA	2-Breakfast 1	2160	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
1-FC-1 Lobby-Trm	Uncontrolled	1	NA	NA	NA	1-FC-1 Lobby	1400	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
19-Office 2-Trm	Uncontrolled	1	NA	NA	NA	19-Office 2	370	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
20-Office 3-Trm	Uncontrolled	1	NA	NA	NA	20-Office 3	370	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 27 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

B. ZONAL SYSTEM AND TERMINAL UNIT SUMMARY													§ 140.4	
1.	2.	3.	4.		5.	6.	7.			8.			Confirmed	
System ID	System Type	Qty	Rated Capacity (kBtuh)		Economizer	Zone Name	Airflow (cfm)			Fan			Pass	Fail
			Heating	Cooling			Design	Min.	Min. Ratio	BHP	Cycles	ECM Motor		
21-Open Office-Trm	Uncontrolled	1	NA	NA	NA	21-Open Office	800	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
24-Conference-Trm	Uncontrolled	1	NA	NA	NA	24-Conference	247	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
23-Temple Room-Trm	Uncontrolled	1	NA	NA	NA	23-Temple Room	127	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
22-Office 1-Trm	Uncontrolled	1	NA	NA	NA	22-Office 1	226	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

C. EXHAUST FAN SUMMARY
This Section Does Not Apply

D. DHW EQUIPMENT SUMMARY – (Adapted from NRCC-PLB-01)										§ 110.3		Confirmed	
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	Pass	Fail
DHW Name	Heater Element Type	Tank Type	Qty	Tank Vol (gal)	Rated Input (kBtu/h)	Efficiency	Tank Insulation R-value (Int/Ext)	Pilot Energy (Btu/h)	Standby Loss	Heat Pump Type	Tank Location or Ambient Condition		
Intellihot iQ7511	Gas	Instantaneous	2	2	1502	ThrmI. Eff.: 0.940	NA		0	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>
Intellihot iQ7511 2	Gas	Instantaneous	22	1	751	ThrmI. Eff.: 0.940	0.0 / 0.0	0	NA	NA	Unconditioned	<input type="checkbox"/>	<input type="checkbox"/>

E. MULTI-FAMILY CENTRAL DHW SYSTEM DETAILS										\$ 110.3	Confirmed	
1.	2.	3.	4.	5.	6.	7.		8.	9.	10.	Pass	Fail
System Name	Number of Dwelling Units Served by System	System Type	Number of Water Heaters / System	Multi-Family Distribution Type	Solar Fraction (%)	Recirculating Pump		Number of Recirculation Loops	Recirculation Loop Insulation Thickness	Recirculation Loop Location		
						Eff	BHP					
MF-Intellihot iQ7511	11	Standard	22	NA	0.00	NA	NA	NA	NA	NA	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 28 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

F. SOLAR HOT WATER HEATING SUMMARY (Adapted from NRCC-STH-01)

This Section Does Not Apply

G. MECHANICAL HVAC ACCEPTANCE TESTS & FORMS (Adapted from 2016-NRCC-MCH-01-E)

§ RA4

Declaration of Required Acceptance Certificates (NRCA) – Acceptance Certificates that may be submitted. (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify).

Test Description		MCH-02A	MCH-03A	MCH-04A	MCH-05A	MCH-06A	MCH-07A	MCH-08A	MCH-09A	MCH-10A	MCH-11A	MCH-12A	MCH-13A	MCH-14A	MCH-15A	MCH-16A	MCH-17A	MCH-18A	Confirmed	
Equipment Requiring Testing or Verification	# of units	Outdoor Air	Single Zone Unitary	Air Dist. Ducts	Economizer Controls	DCV	Supply Fan VAV	Valve leakage	Supply Water Temp. Reset	Hyd. Variable Flow Control	Auto Demand Shed Control	FDD for DX Units	Auto FDD for Air & Zone	Dist. Energy Storage DX AC	TES Systems	Supply Air Temp. Reset	Condenser Water Reset Controls	ECMS	Pass	Fail
Gateway Hotel2 - SHW	1	--	--	--	--	--	--	--	X	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
DOAS	1	X	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-18 6th Office 2	1	X	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-19 6th Office 3	1	X	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-20 6th Open Office	1	X	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-21 6th Office 1/Temple	1	X	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-1 Lobby	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-2 Breakfast 1	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 29 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

G. MECHANICAL HVAC ACCEPTANCE TESTS & FORMS (Adapted from 2016-NRCC-MCH-01-E)																			§ RA4	
Declaration of Required Acceptance Certificates (NRCA) – Acceptance Certificates that may be submitted. (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify).																				
Test Description		MCH-02A	MCH-03A	MCH-04A	MCH-05A	MCH-06A	MCH-07A	MCH-08A	MCH-09A	MCH-10A	MCH-11A	MCH-12A	MCH-13A	MCH-14A	MCH-15A	MCH-16A	MCH-17A	MCH-18A	Confirmed	
																			Fail	Pass
Equipment Requiring Testing or Verification	# of units	Outdoor Air	Single Zone Unitary	Air Dist. Ducts	Economizer Controls	DCV	Supply Fan VAV	Valve leakage	Supply Water Temp. Reset	Hyd. Variable Flow Control	Auto Demand Shed Control	FDD for DX Units	Auto FDD for Air & Zone	Dist. Energy Storage DX AC	TES Systems	Supply Air Temp. Reset	Condenser Water Reset Controls	ECMS		
FC-3 Food Prep	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-4 Corridor 2	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-5 Fitness	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-6 Game Room	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-7 Breakfast 2	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-8 Meeting Room 1	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-9 Meeting Room 2	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-10 Corridor/RR	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-11 Laundry	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-12 Offices	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 30 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

G. MECHANICAL HVAC ACCEPTANCE TESTS & FORMS (Adapted from 2016-NRCC-MCH-01-E)																			§ RA4	
Declaration of Required Acceptance Certificates (NRCA) – Acceptance Certificates that may be submitted. (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify).																				
Test Description		MCH-02A	MCH-03A	MCH-04A	MCH-05A	MCH-06A	MCH-07A	MCH-08A	MCH-09A	MCH-10A	MCH-11A	MCH-12A	MCH-13A	MCH-14A	MCH-15A	MCH-16A	MCH-17A	MCH-18A	Confirmed	
																			Fail	Pass
Equipment Requiring Testing or Verification	# of units	Outdoor Air	Single Zone Unitary	Air Dist. Ducts	Economizer Controls	DCV	Supply Fan VAV	Valve leakage	Supply Water Temp. Reset	Hyd. Variable Flow Control	Auto Demand Shed Control	FDD for DX Units	Auto FDD for Air & Zone	Dist. Energy Storage DX AC	TES Systems	Supply Air Temp. Reset	Condenser Water Reset Controls	ECMS		
FC-13 Offices	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-14 2nd Corridor	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-15 3rd Corridor	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-16 4th Corridor	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-17 5th Corridor	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
FC-23 PBX	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #101	2	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #105	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #139	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #140	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #141	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #142	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
Suite #143	1	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 31 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

G. MECHANICAL HVAC ACCEPTANCE TESTS & FORMS (Adapted from 2016-NRCC-MCH-01-E)																			§ RA4	
Declaration of Required Acceptance Certificates (NRCA) – Acceptance Certificates that may be submitted. (Retain copies and verify forms are completed and signed to post in field for Field Inspector to verify).																				
Test Description		MCH-02A	MCH-03A	MCH-04A	MCH-05A	MCH-06A	MCH-07A	MCH-08A	MCH-09A	MCH-10A	MCH-11A	MCH-12A	MCH-13A	MCH-14A	MCH-15A	MCH-16A	MCH-17A	MCH-18A	Confirmed	
Equipment Requiring Testing or Verification	# of units	Outdoor Air	Single Zone Unitary	Air Dist. Ducts	Economizer Controls	DCV	Supply Fan VAV	Valve leakage	Supply Water Temp. Reset	Hyd. Variable Flow Control	Auto Demand Shed Control	FDD for DX Units	Auto FDD for Air & Zone	Dist. Energy Storage DX AC	TES Systems	Supply Air Temp. Reset	Condenser Water Reset Controls	ECMS	Fail	Pass
																			<input type="checkbox"/>	<input type="checkbox"/>
																			<input type="checkbox"/>	<input type="checkbox"/>
																			<input type="checkbox"/>	<input type="checkbox"/>
																			<input type="checkbox"/>	<input type="checkbox"/>
2nd - Guest Rooms	38	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
3rd - Guest Rooms	38	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
4th - Guest Rooms	38	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>
5th - Guest Rooms	38	X	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	<input type="checkbox"/>	<input type="checkbox"/>

H. EVAPORATIVE COOLER SUMMARY
This Section Does Not Apply

NRCC-PRF-LTI-DETAILS -SECTION START-

A. INDOOR CONDITIONED LIGHTING CONTROL CREDITS (Adapted from NRCC-LTI-02-E)	§ 140.6
This Section Does Not Apply	

B. INDOOR CONDITIONED LIGHTING MANDATORY LIGHTING CONTROLS (Adapted from NRCC-LTI-02-E)	§ 130.1
This Section Does Not Apply	

Project Name:	Gateway Hotel	NRCC-PRF-01-E	Page 32 of 32
Project Address:	550 Gateway Boulevard South San Francisco 94080	Calculation Date/Time:	11:37, Sat, Oct 14, 2017
Compliance Scope:	NewEnvelopeAndMechanical	Input File Name:	M16095-T24.cibd16x

C. TAILORED METHOD CONDITIONED LIGHTING POWER ALLOWANCE SUMMARY AND CHECKLIST (Adapted from NRCC-LTI-04-E)	§ 140.6
This Section Does Not Apply	

D. GENERAL LIGHTING POWER (Adapted from NRCC-LTI-04-E)	§ 140.6-D
This Section Does Not Apply	

E. GENERAL LIGHTING FROM SPECIAL FUNCTION AREAS (Adapted from NRCC-LTI-04-E)	§ 140.6(c) 3H
This Section Does Not Apply	

F. ROOM CAVITY RATIO (Adapted from NRCC-LTI-04-E)
This Section Does Not Apply

G. ADDITIONAL "USE IT OR LOSE IT" (Adapted from NRCC-LTI-04-E)
This Section Does Not Apply

H. INDOOR & OUTDOOR LIGHTING ACCEPTANCE TESTS & FORMS (Adapted from NRCC-LTI-01-E and NRCC-LTO-01-E)	§ 130.4
This Section Does Not Apply	

ENVELOPE MANDATORY MEASURES: NONRESIDENTIAL		ENV-MM
Project Name Gateway Hotel		Date 10/14/2017
DESCRIPTION		
Building Envelope Measures:		
§110.8(a):	Installed insulating material shall have been certified by the manufacturer to comply with the California Quality Standards for insulating material, Title 20 Chapter 4, Article 3.	
§110.8(c):	All Insulating Materials shall be installed in compliance with the flame spread rating and smoke density requirements of Sections 2602 and 707 of Title 24, Part 2.	
§110.8(g):	Heated slab floors shall be insulated according to the requirements in Table 110.8-A.	
§110.7(a):	All Exterior Joints and openings in the building that are observable sources of air leakage shall be caulked, gasketed, weatherstripped or otherwise sealed.	
§110.6(a):	Manufactured fenestration products and exterior doors shall have air infiltration rates not exceeding 0.3 cfm/ft. ² of window area, 0.3 cfm/ft. ² of door area for residential doors, 0.3 cfm/ft. ² of door area for nonresidential single doors (swinging and sliding), and 1.0 cfm/ft. ² for nonresidential double doors (swinging).	
§110.6(a):	Fenestration U-factor shall be rated in accordance with NFRC 100, or the applicable default U-factor.	
§110.6(a) :	Fenestration SHGC shall be rated in accordance with NFRC 200, or NFRC 100 for site-built fenestration, or the applicable default SHGC.	
§110.6(b):	Site Constructed Doors, Windows and Skylights shall be caulked between the unit and the building, and shall be weatherstripped (except for unframed glass doors and fire doors).	
§120.7(a):	<p>The opaque portions of the roof/ceiling that separates conditioned spaces from unconditioned spaces or ambient air shall meet the applicable U-Factor requirements as follows:</p> <p>Metal Building- The weighted average U-factor of the roof assembly shall not exceed 0.098. Wood Framed and Others- The weighted average U-factor of the roof assembly shall not exceed 0.075.</p>	
§120.7(b):	<p>The opaque portions of walls that separate conditioned spaces from unconditioned spaces or ambient air shall meet the applicable U-factor as follows:</p> <p>Metal Building- The weighted average U-factor of the wall assembly shall not exceed 0.113. Metal Framed- The weighted average U-factor of the wall assembly shall not exceed 0.151. Light Mass Walls- A 6 inch or greater Hollow Core Concrete Masonry Unit shall have a U-factor not to exceed 0.440. Heavy Mass Walls- An 8 inch or greater Hollow Core Concrete Masonry Unit shall have a U-factor not to exceed 0.690. Wood Framed and Others- The weighted average U-factor of the wall assembly shall not exceed 0.110. Spandrel Panels and Opaque Curtain Wall- The weighted average U-factor of the spandrel panels and opaque curtain wall assembly shall not exceed 0.280. Demising Walls-. The opaque portions of framed demising walls shall meet the requirements of Item A or B below: A. Wood framed walls shall be insulated to meet a U-factor not greater than 0.099. B. Metal Framed walls shall be insulated to meet a U-factor not greater than 0.151.</p>	
§120.7(c):	<p>The opaque portions of floors and soffits that separate conditioned spaces from unconditioned spaces or ambient air shall meet the applicable U-Factor requirements as follows:</p> <p>Raised Mass Floors- Shall have a minimum of 3 inches of lightweight concrete over a metal deck or the weighted average U-factor of the floor assembly shall not exceed 0.269. Other Floors-The weighted average U-factor of the floor assembly shall not exceed 0.071.</p>	


HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-1 Lobby	Floor Area 1,850


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	39,426		1,627	30,273	4,625	739
Total Output (Btuh)	39,426			0		21,583
Output (Btuh/sqft)	21.3			1,514		1,079
Cooling System				0		0
Output per System	44,057		278	0	0	278
Total Output (Btuh)	44,057			1,160		-1,160
Total Output (Tons)	3.7			1,514		1,079
Total Output (Btuh/sqft)	23.8					
Total Output (sqft/Ton)	503.9			34,461	4,625	22,581

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,400	PEFY-P48NMAU-E3	35,155	9,270		28,753
Airflow (cfm)	1,400					
Airflow (cfm/sqft)	0.76					
Airflow (cfm/Ton)	381.3					
Outside Air (%)	19.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		35,155	9,270	28,753
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Jun 5 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-2 Breakfast 1	Floor Area 1,925


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	80,000		2,662	48,192	27,185	536
Total Output (Btuh)	80,000			0		16,130
Output (Btuh/sqft)	41.6			2,410		806
Cooling System				0		0
Output per System	72,252		783	0	0	783
Total Output (Btuh)	72,252			2,799		-2,799
Total Output (Tons)	6.0			2,410		806
Total Output (Btuh/sqft)	37.5					
Total Output (sqft/Ton)	319.7			55,809	27,185	14,944

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	2,160	PEFY-P72NMHSU-E	55,196	26,023		58,344
Airflow (cfm)	2,160					
Airflow (cfm/sqft)	1.12					
Airflow (cfm/Ton)	358.7					
Outside Air (%)	36.3 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		55,196	26,023	58,344
Outside Air (cfm/sqft)	0.41	TIME OF SYSTEM PEAK		Jun 9 AM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-3 Food Prep	Floor Area 453


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	13,500		264	5,020	1,076	30
Total Output (Btuh)	13,500			0		
Output (Btuh/sqft)	29.8			251		45
Cooling System				0		0
Output per System	12,000		68	0	0	68
Total Output (Btuh)	12,000			307		-307
Total Output (Tons)	1.0			251		45
Total Output (Btuh/sqft)	26.5					
Total Output (sqft/Ton)	453.0			5,829	1,076	675

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	370	PEFY-P12NMAU-E3				
Airflow (cfm)	370		9,938	2,974		9,846
Airflow (cfm/sqft)	0.82					
Airflow (cfm/Ton)	370.0					
Outside Air (%)	18.4 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		9,938	2,974	9,846
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Jul 8 AM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-4 Corridor 2	Floor Area 695


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	13,500		236	4,502	1,738	40
Total Output (Btuh)	13,500			0		
Output (Btuh/sqft)	19.4			225		59
Cooling System				0		0
Output per System	12,000		104	0	0	104
Total Output (Btuh)	12,000			307		-307
Total Output (Tons)	1.0			225		59
Total Output (Btuh/sqft)	17.3					
Total Output (sqft/Ton)	695.0			5,260	1,738	998

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	370	PEFY-P12NMAU-E3				
Airflow (cfm)	370		9,615	3,313		9,846
Airflow (cfm/sqft)	0.53					
Airflow (cfm/Ton)	370.0					
Outside Air (%)	28.2 %	Total Adjusted System Output (Adjusted for Peak Design conditions)				
Outside Air (cfm/sqft)	0.15		9,615	3,313		9,846
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK			Jun 9 AM	Jan 1 AM

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-5 Fitness	Floor Area 630


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	19,713		599	11,420	11,025	126
Total Output (Btuh)	19,713			0		3,721
Output (Btuh/sqft)	31.3			571		186
Cooling System				0		0
Output per System	22,029		95	0	0	95
Total Output (Btuh)	22,029			580		-580
Total Output (Tons)	1.8			571		186
Total Output (Btuh/sqft)	35.0					
Total Output (sqft/Ton)	343.2			13,143	11,025	3,513

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	800	PEFY-P24NMAU-E3	14,142	9,243		14,377
Airflow (cfm)	800					
Airflow (cfm/sqft)	1.27					
Airflow (cfm/Ton)	435.8					
Outside Air (%)	11.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		14,142	9,243	14,377
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-6 Game Room	Floor Area 368


ENGINEERING CHECKS		SYSTEM LOAD						
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK		COIL HTG. PEAK			
Heating System			CFM	Sensible	Latent	CFM	Sensible	
Output per System	19,713		609	11,611	6,747	63	1,874	
Total Output (Btuh)	19,713			0				
Output (Btuh/sqft)	53.6			581			94	
Cooling System				0			0	
Output per System	22,029		Ventilation	184	0	0	184	0
Total Output (Btuh)	22,029		Supply Fan		580			-580
Total Output (Tons)	1.8		Supply Air Ducts		581			94
Total Output (Btuh/sqft)	59.9							
Total Output (sqft/Ton)	200.5							
				13,352	6,747		1,482	

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	800	PEFY-P24NMAU-E3				
Airflow (cfm)	800	15,519				
Airflow (cfm/sqft)	2.17	7,230				
Airflow (cfm/Ton)	435.8					
Outside Air (%)	23.0 %	Total Adjusted System Output				
Outside Air (cfm/sqft)	0.50	(Adjusted for Peak Design conditions)				
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)



Project Name Gateway Hotel	Date 10/14/2017
System Name FC-7 Breakfast 2	Floor Area 886

Air System						
CFM per System	1,160	HVAC EQUIPMENT SELECTION				
Airflow (cfm)	1,160	PEFY-P36NMAU-E3	25,951	12,001		29,172
Airflow (cfm/sqft)	1.31					
Airflow (cfm/Ton)	385.7					
Outside Air (%)	33.4 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	25,951	12,001		29,172
Outside Air (cfm/sqft)	0.44					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Sep 4 PM		Jan 1 AM	

Jan 1 AM

The diagram illustrates a single duct, single zone system. It shows the flow of air from the outside air intake, through the supply fan, heating coil, and into the room. The return air is drawn from the room and passes through the heating coil before being exhausted. The temperatures and flow rates are indicated at various points in the system.

78 / 63 °F 75 / 65 °F 75 / 65 °F 55 / 54 °F

Outside Air
387 cfm

Supply Fan
1,160 cfm

Cooling Coil

61.7 %

ROOM

56 / 55 °F

74 / 65 °F

75 / 65 °F


HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-8 Meeting Room 1	Floor Area 662


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	40,000		835	15,960	6,841	54
Total Output (Btuh)	40,000			0		1,607
Output (Btuh/sqft)	60.4			798		80
Cooling System				0		0
Output per System	36,090		331	0	0	331
Total Output (Btuh)	36,090			819		-819
Total Output (Tons)	3.0			798		80
Total Output (Btuh/sqft)	54.5					
Total Output (sqft/Ton)	220.1			18,375	6,841	949

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3				
Airflow (cfm)	1,160	32,502				
Airflow (cfm/sqft)	1.75	7,171				
Airflow (cfm/Ton)	385.7					
Outside Air (%)	28.5 %	Total Adjusted System Output				
Outside Air (cfm/sqft)	0.50	(Adjusted for Peak Design conditions)				
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK				
		Jan 10 PM				
		Jan 1 AM				

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-9 Meeting Room 2	Floor Area 698


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	40,000		1,001	19,013	7,213	91
Total Output (Btuh)	40,000			0		
Output (Btuh/sqft)	57.3			951		135
Cooling System				0		0
Output per System	36,090		349	0	0	349
Total Output (Btuh)	36,090			819		-819
Total Output (Tons)	3.0			951		135
Total Output (Btuh/sqft)	51.7					
Total Output (sqft/Ton)	232.1			21,733	7,213	2,152

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3				
Airflow (cfm)	1,160	28,914				
Airflow (cfm/sqft)	1.66	9,278				
Airflow (cfm/Ton)	385.7					
Outside Air (%)	30.1 %	28,914				
Outside Air (cfm/sqft)	0.50	9,278				
Note: values above given at ARI conditions		Total Adjusted System Output (Adjusted for Peak Design conditions)				
		TIME OF SYSTEM PEAK Sep 11 AM Jan 1 AM				

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-10 Corridor/RR	Floor Area 1,688


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	19,713		599	11,422	4,220	111
Total Output (Btuh)	19,713			0		3,303
Output (Btuh/sqft)	11.7			571		165
Cooling System				0		0
Output per System	22,029		253	0	0	253
Total Output (Btuh)	22,029			580		-580
Total Output (Tons)	1.8			571		165
Total Output (Btuh/sqft)	13.1					
Total Output (sqft/Ton)	919.5			13,145	4,220	3,053

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	800	PEFY-P24NMAU-E3	16,350	6,021		14,377
Airflow (cfm)	800					
Airflow (cfm/sqft)	0.47					
Airflow (cfm/Ton)	435.8					
Outside Air (%)	31.7 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		16,350	6,021	14,377
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-11 Laundry	Floor Area 1,210


ENGINEERING CHECKS		SYSTEM LOAD						
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK		COIL HTG. PEAK			
Heating System			CFM	Sensible	Latent	CFM	Sensible	
Output per System	40,000		892	17,004	3,025	109	3,250	
Total Output (Btuh)	40,000			0				
Output (Btuh/sqft)	33.1			850			162	
Cooling System				0			0	
Output per System	36,090		Ventilation	182	0	0	182	0
Total Output (Btuh)	36,090		Supply Fan		819			-819
Total Output (Tons)	3.0		Supply Air Ducts		850			162
Total Output (Btuh/sqft)	29.8							
Total Output (sqft/Ton)	402.3				19,524	3,025		2,756

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3				
Airflow (cfm)	1,160	30,000				
Airflow (cfm/sqft)	0.96	6,206				
Airflow (cfm/Ton)	385.7					
Outside Air (%)	15.6 %	Total Adjusted System Output				
Outside Air (cfm/sqft)	0.15	(Adjusted for Peak Design conditions)				
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK				
		Jun 5 PM				
		Jan 1 AM				

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-12 Offices	Floor Area 1,075


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	34,000		866	16,390	2,345	181
Total Output (Btuh)	34,000			0		6,891
Output (Btuh/sqft)	31.6			819		345
Cooling System				0		0
Output per System	30,000		161	0	0	161
Total Output (Btuh)	30,000			580		-580
Total Output (Tons)	2.5			819		345
Total Output (Btuh/sqft)	27.9					
Total Output (sqft/Ton)	430.0			18,609	2,345	7,000

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	880	PEFY-P30NMAU-E3	23,428	7,034		24,796
Airflow (cfm)	880					
Airflow (cfm/sqft)	0.82					
Airflow (cfm/Ton)	352.0					
Outside Air (%)	18.3 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		23,428	7,034	24,796
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Jun 6 PM		Jan 1 AM

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-13 Offices	Floor Area 664


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	14,602		524	9,993	3,918	0
Total Output (Btuh)	14,602			0		0
Output (Btuh/sqft)	22.0			500		0
Cooling System				0		0
Output per System	16,522		204	0	0	204
Total Output (Btuh)	16,522			375		-375
Total Output (Tons)	1.4			500		0
Total Output (Btuh/sqft)	24.9					
Total Output (sqft/Ton)	482.3			11,368	3,918	-375

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	600	PEFY-P18NMAU-E3		13,742	4,543	10,649
Airflow (cfm)	600					
Airflow (cfm/sqft)	0.90					
Airflow (cfm/Ton)	435.8					
Outside Air (%)	34.0 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		13,742	4,543	10,649
Outside Air (cfm/sqft)	0.31					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Jan 10 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-14 2nd Corridor	Floor Area 2,689


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	40,000		890	16,971	6,723	68
Total Output (Btuh)	40,000			0		2,021
Output (Btuh/sqft)	14.9			849		101
Cooling System				0		0
Output per System	36,090		403	0	0	403
Total Output (Btuh)	36,090			819		-819
Total Output (Tons)	3.0			849		101
Total Output (Btuh/sqft)	13.4					
Total Output (sqft/Ton)	894.1			19,488	6,723	1,404

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3	28,505	8,250		29,172
Airflow (cfm)	1,160					
Airflow (cfm/sqft)	0.43					
Airflow (cfm/Ton)	385.7					
Outside Air (%)	34.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		28,505	8,250	29,172
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-15 3rd Corridor	Floor Area 2,689


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	40,000		890	16,971	6,723	68
Total Output (Btuh)	40,000			0		2,021
Output (Btuh/sqft)	14.9			849		101
Cooling System				0		0
Output per System	36,090		403	0	0	403
Total Output (Btuh)	36,090			819		-819
Total Output (Tons)	3.0			849		101
Total Output (Btuh/sqft)	13.4					
Total Output (sqft/Ton)	894.1			19,488	6,723	1,404

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3				
Airflow (cfm)	1,160	28,505				
Airflow (cfm/sqft)	0.43	8,250				
Airflow (cfm/Ton)	385.7					
Outside Air (%)	34.8 %	Total Adjusted System Output				
Outside Air (cfm/sqft)	0.15	(Adjusted for Peak Design conditions)				
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK				
		Sep 4 PM				
		Jan 1 AM				

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-16 4th Corridor	Floor Area 2,689


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	COIL COOLING PEAK			COIL HTG. PEAK	
Heating System		CFM	Sensible	Latent	CFM	Sensible
Output per System	40,000	890	16,971	6,723	68	2,021
Total Output (Btuh)	40,000		0			
Output (Btuh/sqft)	14.9		849			101
Cooling System						
Output per System	36,090	403	0	0	403	0
Total Output (Btuh)	36,090		819			-819
Total Output (Tons)	3.0		849			101
Total Output (Btuh/sqft)	13.4					
Total Output (sqft/Ton)	894.1					
		TOTAL SYSTEM LOAD				
			19,488	6,723		1,404

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3	28,505	8,250		29,172
Airflow (cfm)	1,160					
Airflow (cfm/sqft)	0.43					
Airflow (cfm/Ton)	385.7					
Outside Air (%)	34.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		28,505	8,250	29,172
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-17 5th Corridor	Floor Area 2,689


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	40,000		916	17,462	6,723	90
Total Output (Btuh)	40,000			0		2,691
Output (Btuh/sqft)	14.9			873		135
Cooling System				0		0
Output per System	36,090		403	0	0	403
Total Output (Btuh)	36,090			819		-819
Total Output (Tons)	3.0			873		135
Total Output (Btuh/sqft)	13.4					
Total Output (sqft/Ton)	894.1			20,028	6,723	2,141

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	1,160	PEFY-P36NMAU-E3				
Airflow (cfm)	1,160		28,476	8,172		29,172
Airflow (cfm/sqft)	0.43					
Airflow (cfm/Ton)	385.7					
Outside Air (%)	34.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		28,476	8,172	29,172
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Sep 3 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-18 6th Office 2	Floor Area 364


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	13,500		277	5,251	728	75
Total Output (Btuh)	13,500			0		
Output (Btuh/sqft)	37.1			263		112
Cooling System				0		0
Output per System	12,000		55	339	149	55
Total Output (Btuh)	12,000			307		-307
Total Output (Tons)	1.0			263		112
Total Output (Btuh/sqft)	33.0					
Total Output (sqft/Ton)	364.0			6,422	877	4,378

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	370	PEFY-P12NMAU-E3				
Airflow (cfm)	370		9,846	2,070		9,846
Airflow (cfm/sqft)	1.02					
Airflow (cfm/Ton)	370.0					
Outside Air (%)	14.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		9,846	2,070	9,846
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Jul 2 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-19 6th Office 3	Floor Area 366


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	COIL COOLING PEAK			COIL HTG. PEAK	
Heating System		CFM	Sensible	Latent	CFM	Sensible
Output per System	13,500	314	5,929	732	76	2,243
Total Output (Btuh)	13,500		0			
Output (Btuh/sqft)	36.9		296			112
Cooling System						
Output per System	12,000	55	371	150	55	2,236
Total Output (Btuh)	12,000		307			-307
Total Output (Tons)	1.0		296			112
Total Output (Btuh/sqft)	32.8					
Total Output (sqft/Ton)	366.0					
		TOTAL SYSTEM LOAD				

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	370	PEFY-P12NMAU-E3				9,846
Airflow (cfm)	370					
Airflow (cfm/sqft)	1.01					
Airflow (cfm/Ton)	370.0					
Outside Air (%)	14.8 %	Total Adjusted System Output (Adjusted for Peak Design conditions)				9,846
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK			Aug 3 PM	Jan 1 AM

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-20 6th Open Office	Floor Area 1,262


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	19,713		727	13,768	3,056	219
Total Output (Btuh)	19,713			0		
Output (Btuh/sqft)	15.6			688		322
Cooling System				0		0
Output per System	22,029		189	1,268	154	189
Total Output (Btuh)	22,029			580		-580
Total Output (Tons)	1.8			688		322
Total Output (Btuh/sqft)	17.5					
Total Output (sqft/Ton)	687.5			16,993	3,209	14,201

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	800	PEFY-P24NMAU-E3	17,519	4,548		14,377
Airflow (cfm)	800					
Airflow (cfm/sqft)	0.63					
Airflow (cfm/Ton)	435.8					
Outside Air (%)	23.7 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	17,519	4,548		14,377
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Aug 3 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)



Project Name Gateway Hotel	Date 10/14/2017
System Name FC-21 6th Office 1/Temple/Conf	Floor Area 497

Air System						
CFM per System	600	HVAC EQUIPMENT SELECTION				
Airflow (cfm)	600	PEFY-P18NMAU-E3	13,057	3,541		10,649
Airflow (cfm/sqft)	1.21					
Airflow (cfm/Ton)	435.8					
Outside Air (%)	24.4 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	13,057	3,541		10,649
Outside Air (cfm/sqft)	0.29					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Jul 3 PM		Jan 1 AM	

32 °F 61 °F 61 °F 97 °F

Outside Air 146 cfm

Supply Fan 600 cfm

Heating Coil

ROOM 70 °F

97 °F

81 / 65 °F 76 / 63 °F 76 / 63 °F 55 / 54 °F

Outside Air
146 cfm

Supply Fan
600 cfm

Cooling Coil

52.2 %

ROOM

56 / 54 °F

74 / 62 °F

75 / 63 °F


HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name FC-23 PBX	Floor Area 154


ENGINEERING CHECKS		SYSTEM LOAD					
Number of Systems	1	<div>Total Room Loads</div> <div>Return Vented Lighting</div> <div>Return Air Ducts</div> <div>Return Fan</div> <div>Ventilation</div> <div>Supply Fan</div> <div>Supply Air Ducts</div> <div>TOTAL SYSTEM LOAD</div>	COIL COOLING PEAK			COIL HTG. PEAK	
Heating System			CFM	Sensible	Latent	CFM	Sensible
Output per System	12,461		25	510	116	0	0
Total Output (Btuh)	12,461			0			
Output (Btuh/sqft)	80.9			25			0
Cooling System				0			0
Output per System	14,775		23	0	0	23	0
Total Output (Btuh)	14,775			102			-102
Total Output (Tons)	1.2			25			0
Total Output (Btuh/sqft)	95.9						
Total Output (sqft/Ton)	125.1			663	116		
						-102	

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	425	PKFY-P18NHMU-E2				
Airflow (cfm)	425		14,923	399		9,088
Airflow (cfm/sqft)	2.76					
Airflow (cfm/Ton)	345.2					
Outside Air (%)	5.4 %	Total Adjusted System Output (Adjusted for Peak Design conditions)		14,923	399	9,088
Outside Air (cfm/sqft)	0.15	TIME OF SYSTEM PEAK		Jan 10 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #101	Floor Area 617


ENGINEERING CHECKS		SYSTEM LOAD					
Number of Systems	2	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK	
Heating System			CFM	Sensible	Latent	CFM	Sensible
Output per System	5,900		286	5,995	478	123	4,865
Total Output (Btuh)	11,800			0			
Output (Btuh/sqft)	19.1			300			243
Cooling System				0			0
Output per System	6,600		93	542	367	93	3,550
Total Output (Btuh)	13,200			6			-6
Total Output (Tons)	1.1			300			243
Total Output (Btuh/sqft)	21.4						
Total Output (sqft/Ton)	560.9			7,142	845	8,895	

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	10,978	2,107		8,606
Airflow (cfm)	480	2.4 kW Supplemental Electric				16,382
Airflow (cfm/sqft)	0.78					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	19.3 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	10,978	2,107		24,988
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Aug 3 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #105	Floor Area 496


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		141	2,948	384	38
Total Output (Btuh)	5,900			0		1,526
Output (Btuh/sqft)	11.9			147		76
Cooling System				0		0
Output per System	6,600		74	436	251	74
Total Output (Btuh)	6,600			3		2,868
Total Output (Tons)	0.6			147		-3
Total Output (Btuh/sqft)	13.3					76
Total Output (sqft/Ton)	901.8			3,682	636	4,544

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,529	1,060		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.48					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	31.0 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,529	1,060		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Aug 3 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #139	Floor Area 359


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		160	3,333	278	36
Total Output (Btuh)	5,900			0		1,409
Output (Btuh/sqft)	16.4			167		70
Cooling System				0		0
Output per System	6,600		54	160	34	54
Total Output (Btuh)	6,600			3		2,077
Total Output (Tons)	0.6			167		-3
Total Output (Btuh/sqft)	18.4					70
Total Output (sqft/Ton)	652.7					
				3,830	313	3,624

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,502	1,099		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.67					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	22.4 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,502	1,099		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Sep 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #140	Floor Area 363


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		116	2,444	281	36
Total Output (Btuh)	5,900			0		1,412
Output (Btuh/sqft)	16.3			122		71
Cooling System				0		0
Output per System	6,600		54	325	206	54
Total Output (Btuh)	6,600			3		2,100
Total Output (Tons)	0.6			122		-3
Total Output (Btuh/sqft)	18.2					71
Total Output (sqft/Ton)	660.0					3,650

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,486	1,068		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.66					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	22.7 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,486	1,068		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Jul 3 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #141	Floor Area 395


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		164	3,431	306	37
Total Output (Btuh)	5,900			0		1,485
Output (Btuh/sqft)	14.9			172		74
Cooling System				0		0
Output per System	6,600		59	303	219	59
Total Output (Btuh)	6,600			3		2,284
Total Output (Tons)	0.6			172		-3
Total Output (Btuh/sqft)	16.7					74
Total Output (sqft/Ton)	718.2			4,080	526	3,915

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,500	1,082		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.61					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	24.7 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,500	1,082		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Aug 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #142	Floor Area 369


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		118	2,479	286	37
Total Output (Btuh)	5,900			0		1,459
Output (Btuh/sqft)	16.0			124		73
Cooling System				0		0
Output per System	6,600		55	330	208	55
Total Output (Btuh)	6,600			3		2,134
Total Output (Tons)	0.6			124		-3
Total Output (Btuh/sqft)	17.9					73
Total Output (sqft/Ton)	670.9			3,060	494	3,736

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,488	1,068		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.65					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	23.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,488	1,068		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Jul 3 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name Suite #143	Floor Area 401


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	1	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		183	3,805	311	87
Total Output (Btuh)	5,900			0		
Output (Btuh/sqft)	14.7			190		170
Cooling System				0		0
Output per System	6,600		60	303	222	60
Total Output (Btuh)	6,600			3		-3
Total Output (Tons)	0.6			190		170
Total Output (Btuh/sqft)	16.5					
Total Output (sqft/Ton)	729.1			4,492	533	6,029

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	5,510	1,076		4,303
Airflow (cfm)	240	2.4 kW Supplemental Electric				8,191
Airflow (cfm/sqft)	0.60					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	25.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	5,510	1,076		12,494
Outside Air (cfm/sqft)	0.15					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Aug 4 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name 2nd - Guest Rooms	Floor Area 16,206


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	38	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		4,956	104,113	6,663	1,042
Total Output (Btuh)	224,200			0		41,415
Output (Btuh/sqft)	13.8			5,206		2,071
Cooling System				0		0
Output per System	6,600		1,290	6,782	5,456	1,290
Total Output (Btuh)	250,800			113		-113
Total Output (Tons)	20.9			5,206		2,071
Total Output (Btuh/sqft)	15.5					
Total Output (sqft/Ton)	775.4					
				121,419	12,119	95,272

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM				
Airflow (cfm)	9,120	2.4 kW Supplemental Electric				
Airflow (cfm/sqft)	0.56					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	14.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)				
Outside Air (cfm/sqft)	0.08					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK		Jul 4 PM	Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name 3rd - Guest Rooms	Floor Area 16,206


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	38	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		4,956	104,113	6,663	1,042
Total Output (Btuh)	224,200			0		41,415
Output (Btuh/sqft)	13.8			5,206		2,071
Cooling System				0		0
Output per System	6,600		1,290	6,782	5,456	1,290
Total Output (Btuh)	250,800			113		49,828
Total Output (Tons)	20.9			5,206		-113
Total Output (Btuh/sqft)	15.5					2,071
Total Output (sqft/Ton)	775.4					95,272

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	207,528	40,865		163,508
Airflow (cfm)	9,120	2.4 kW Supplemental Electric				311,266
Airflow (cfm/sqft)	0.56					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	14.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	207,528	40,865		474,774
Outside Air (cfm/sqft)	0.08					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Jul 4 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name 4th - Guest Rooms	Floor Area 16,206


ENGINEERING CHECKS		SYSTEM LOAD				
Number of Systems	38	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK			COIL HTG. PEAK
Heating System			CFM	Sensible	Latent	CFM
Output per System	5,900		4,956	104,113	6,663	1,042
Total Output (Btuh)	224,200			0		41,415
Output (Btuh/sqft)	13.8			5,206		2,071
Cooling System				0		0
Output per System	6,600		1,290	6,782	5,456	1,290
Total Output (Btuh)	250,800			113		-113
Total Output (Tons)	20.9			5,206		2,071
Total Output (Btuh/sqft)	15.5					
Total Output (sqft/Ton)	775.4					95,272

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM	207,528	40,865		163,508
Airflow (cfm)	9,120	2.4 kW Supplemental Electric				311,266
Airflow (cfm/sqft)	0.56					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	14.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)	207,528	40,865		474,774
Outside Air (cfm/sqft)	0.08					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK	Jul 4 PM		Jan 1 AM	

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)




HVAC SYSTEM HEATING AND COOLING LOADS SUMMARY

Project Name Gateway Hotel	Date 10/14/2017
System Name 5th - Guest Rooms	Floor Area 16,206

ENGINEERING CHECKS		SYSTEM LOAD						
Number of Systems	38	Total Room Loads Return Vented Lighting Return Air Ducts Return Fan Ventilation Supply Fan Supply Air Ducts TOTAL SYSTEM LOAD	COIL COOLING PEAK		COIL HTG. PEAK			
Heating System			CFM	Sensible	Latent	CFM	Sensible	
Output per System	5,900		5,648	118,227	6,663	1,450	57,492	
Total Output (Btuh)	224,200			0				
Output (Btuh/sqft)	13.8			5,911			2,875	
Cooling System				0			0	
Output per System	6,600							
Total Output (Btuh)	250,800		Ventilation	1,290	7,518	5,460	1,290	49,715
Total Output (Tons)	20.9		Supply Fan		113			-113
Total Output (Btuh/sqft)	15.5		Supply Air Ducts		5,911			2,875
Total Output (sqft/Ton)	775.4							

Air System		HVAC EQUIPMENT SELECTION				
CFM per System	240	AZ65H07DAM				
Airflow (cfm)	9,120	2.4 kW Supplemental Electric				
Airflow (cfm/sqft)	0.56					
Airflow (cfm/Ton)	436.4					
Outside Air (%)	14.1 %	Total Adjusted System Output (Adjusted for Peak Design conditions)				
Outside Air (cfm/sqft)	0.08					
Note: values above given at ARI conditions		TIME OF SYSTEM PEAK			Jul 3 PM	Jan 1 AM

HEATING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Heating Peak)



COOLING SYSTEM PSYCHROMETRICS (Airstream Temperatures at Time of Cooling Peak)

