



April 11th, 2017

RE: Home2 Suites by Hilton Jackson / Flowood (Airport Area), MS
Project #14-140
Plumbing Sumittal Review

Below are my comments regarding your plumbing submittal received on March 31, 2017:

## WC-1: ADA Water Closet

1. Dual-flush capability is no longer required. A low-flow (1.28 gpf), WaterSense toilet is an acceptable alternative. Toilet must be fully skirted.

## WC-2: Water Closet

1. Dual-flush capability is no longer required. A low-flow (1.28 gpf), WaterSense toilet is an acceptable alternative. Toilet must be fully skirted.





































## **END OF COMMENTS**

## ADDITIONAL MEP COMMENTS FROM OUR IN-HOUSE ENGINEERING TEAM TO FOLLOW

This review of your drawings, specifications, site conditions, or construction progress is limited to conformance with aesthetic and functional layout and design, and certain functional, operational, and quality criteria as specified by Hilton. It does not encompass, and Hilton does not make any representation and warranty as to, nor shall be responsible for, the architectural, structural, mechanical, or electrical safety, adequacy, integrity or efficiency of the design or compliance with applicable government or other legal requirements. All Hilton Licensees must comply with the Americans with Disabilities Act as well as State and local codes for accessible facilities, Hilton's fire safety, and security equipment standards, and all applicable local, state, and federal building codes. Any omissions in this review do not constitute a waiver and do not release the licensee's responsibility to conform to the criteria established by Hilton.

Sincerely,

Greg Wolf

Director – Southeast Region Focused Service Brands Architecture & Construction

Crey R Wolf

Gregory.Wolf@hilton.com



