

NEVELS ELECTRIC FIRE ALARM

GENERAL NOTES THIS SHEET:

- 1.) INCREASE THE WIRE SIZE A MINIMUM OF ONE SIZE ON ALL 120V. HOME-RUNS OVER 100 FEET IN LENGTH. INCREASE THE WIRE SIZE A MINIMUM OF ONE SIZE FOR ALL 208V. HOME-RUNS OVER 150 FEET IN LENGTH.
- 2.) VERIFY THE ELECTRICAL REQUIREMENTS OF ALL MECHANICAL EQUIPMENT WITH THE MECHANICAL CONTRACTOR AND HIS SUPPLIER PRIOR TO ROUGH-IN.

1 ELECTRICAL FIFTH FLOOR PLAN
1/8"=1'-0" 12,88.35 SQ. FT.

Richard Molenaar
ARCHITECT

INNOVATIVE • ENGINEERING
SERVICES, LLC

2787 Stage Center Dr.
Suite 101
Bartlett, Tennessee 38134
901-379-0500
www.innovativees-llc.com

PROJECT NAME:

HOME2
SUITES BY HILTON

Old Fannin Road Flowood, Mississippi

SHEET TITLE:
ELECTRICAL
FIFTH FLOOR PLAN

PROJECT NO.
13010
DRAWN BY:
PTH
DATE:
08/23/16

LATEST REVISION:
08/23/16

SHEET NUMBER:

E206



E206