IMPORTANT

In localities subject to freezing conditions, it is the owner's responsibility to provide heat throughout wet pipe sprinkler system areas and in enclosures for dry pipe deluge and other types of valves controlling water supplies to sprinkler systems.

This drawing and the information and design application herein contained is the property of VFP Fire Systems , Inc. and is loaned upon the express condition that the same be returned to VFP upon request; all information herein shall be treated as secret and confidential; no reproduction of this drawing or any part thereof shall be made without the written consent of VFP.

PAUL M. GIFFORD

NICET LEVEL 4

Paul M. Gifford

CERTIFICATION NO. 81305

STATE OF MS. PERMIT NO. 11749-SC

REV. NO.	DESCRIPTION	BY	DATE
1	ADJUSTED FIRE PUMP LOCATION AND FDC IN RELATION TO HYDRANT	CJ	07-20-2017

N W E S

SYSTEM TYPE

WET 6" X DELUGE ___

DRY ___ PREACTION ___

APPROVALS

	OUT	IN
SFM		
IRI		
FM/GLOBAL		
X OWNER		
X CITY OF FLOWOOD		

DESCRIPTION: **FP SITE PLAN**

SYSTEM DESIGN DATA

HAZARD CLASSIFICATION: SYSTEM AREA:

HYDRAULIC DESIGN DATA: DENSITY GPM/SQ.FT. SQ.FT./HD.

AREA OF APPLICATION: HOSE ALLOWANCES: GPM.

TOTAL SYSTEM REQUIREMENTS:

WATER SUPPLY: STATIC PRESSURE: *155 PSI* RESIDUAL PRESSURE: *131 PSI*

FLOWING: *750 GPM* LOCATION: *OLD FANNIN RD. @ HOSPITALITY DR. FLOWOOD, MS.*

WATER SUPPLY TESTED BY: *COMBINED CITY AND FIRE PUMP RATED CAPACITY 02/07/2017*

CONTRACT NAME: HOME 2 SUITES BY HILTON

FLOWOOD, MS

CONTRACT WITH:

VFP FIRE SYSTEMS

6161-F RANGELINE RD.
THEODORE, AL. 36582
Ph. (251) 443-7234

P.O. Box 190997
MOBILE, AL. 36619
Fax (251) 443-7902

1/8" = 1'-0

VFP CONTRACT NO.: *787405*

DATE: *02/20/2017*

DRAWN BY: *L FICKLING*

CHECK BY: *JD HOWARD*

DRAWING NO. *FP SITE*