

CENTERLINE OF TUB OR SHOWER

4.) THE RECEPTACLES IN THE GUEST BATHROOMS SHALL BE A LEVATON #X7592-GLW GFI NITE-LITE RECEPTACLE MTD UP 48" A,F,F TO THE CENTER OF BOX., 3.) ALL SWITCHES SHALL BE MOUNTED UP 48" ABOVE FLOOR TO CENTER OF BOX, UNLESS NOTED OTHERWISE 2.) ALL RECEPTACLES, TELEPHONE OUTLETS, TV OUTLETS, TV ANTENNA OUTLETS IN GUEST ROOMS SHALL BE MOUNTED 15" ABOVE FLOOR TO CENTER OF BOX UNLESS NOTED OTHERWISE.

I) BACK TO BACK OUTLETS AND THRU WALL TYPE OUTLET BOXES SHALL NOT BE ALLOWED. BOXES SHALL BE OFFSET FROM ROOM TO ROOM TO MINIMIZE TRANSMISSION OF SOUND AND TO MAINTAIN ALL FIRE RATINGS. THE HORIZONTAL SPACE BETWEEN OUTLET BOXES SHALL BE NO LESS THAN 24" OR AS REQUIRED TO MAINTAIN ALL FIRE RATINGS. IN MAKING FIELD ADJUSTMENTS TO ACCOMMODATE THIS REQUIREMENT, THE CONTRACTOR SHALL VERIFY ALL PLUGS, CORDS, CABLES, & WIRES ARE SCREENED BY FF&E AS INTENDED.

2'-10"

10

13

4

5

16

5.) VERIFY ALL DPMENSIONS ϵ MTG, HEIGHTS WITH HOME 2 GUESTROOM LAYOUTS, 19.) ALL SWITCHES IN GUEST ROOMS SHALL BE OF THE LIGHTED TOGGLE TYPE AND MOUNTED UP 48". (B.) FURNISH AND INSTALL ARC - FAULT CIRCUIT BREAKERS FOR ALL GUEST ROOM BEDROOM LIGHTING AND RECEPTACLE CIRCUITS. 17.) COORDINATE EXACT LOCATIONS OF ALL OUTLETS IN KITCHEN AREA WITH MILLWORK, SEE ARCHITECTURAL DRAWINGS. (6) ALL RECEPTACLES IN WET AND/OR DAMP LOCATIONS SHALL BE 5.) BATHROOM EXHAUST FAN SHALL BE CONTROLLED WITH A SEPARATE SWITCH AND THE LIGHT WITH ANOTHER SWITCH. MOUNT LIGHT SWITCH AND THE GFI RECEPTACLE IN GUEST ROOM THROOM UNDER A SINGLE PLATE (WHERE POSSIBLE). SEE GUEST OM BATHROOM WALL SWITCH DETAIL. FURNISH AND INSTALL IN ALL ACCESSIBLE AND HEARING IMPAIRED IEST ROOM A HOTEL ROOM ANNUNCIATOR (EDWARDS #7005-G5 IEST ROOM DOOR ANNUNCIATOR). REFER TO ARCHITECTURAL AWINGS FOR LOCATIONS OF ALL ACCESSIBLE AND HEARING PAIRED GUEST ROOMS. STUB-UP 208V., I-PHASE CIRCUIT BELOW PTAC UNIT AND MAKE NFECTIONS TO OUTLET IN SUB-BASE AS PER MANUFACTURER'S COMMENDATIONS. VERIFY ALL MANUFACTURER'S LOCATIONS, QUIREMENT AND RECOMMENDATIONS WITH MECHANICAL NTRACTOR PRIOR TO ROUGH-IN. PROVIDE ALL FIRE CAULKING AND / OR PUTTY PADS AS CESSARY TO COMPLY WITH ALL LOCAL, STATE, AND NATIONAL E CODES. 120V. HOME-RUNS EXCEEDING 100 FT. IN LENGTH SHALL HAVE A 2E SIZE INCREASED A MINIMUM OF ONE SIZE. WHERE A 208V. ME-RUN EXCEEDS 150 FT. IN LENGTH, THE WIRE SIZE SHALL BE REASED A MINIMUM OF ONE SIZE. GUEST ROOM SMOKE DETECTORS SHALL BE 120V. STAND ALONE THEY SHALL BE INSTALLED AS DIRECTED BY THE LOCAL FIRE INSTALL, GUEST ROOMS WITH MULTIPLE DETECTORS SHALL BE ERLOCKED. SINGLE STATION SMOKE DETECTORS IN ALL HEARING VARED AND ACCESSIBLE GUEST ROOMS SHALL HAVE A 177 NDELA MINIMUM STROBE. THESE DETECTORS SHALL BE GENTEX 9CS-C OR APPROVED EQUIAL. ALL WIRING DEVICES SHALL BE COMMERCIAL GRADE, FURNISH AND INSTALL A FIRE ALARM SYSTEM AUDIO / VISUALICE IN EACH ACCESSIBLE AND HEARING IMPAIRED GUEST ROOM BATHROOM CONNECTED TO THE BUILDING FIRE ALARM SYSTEM. DEICED IS IN ADDITION TO THE GLEST ROOM 120V, STAND ALONE DETECTOR.



WHIDING C. TURBERVILLE
WHITEG. NO. 25541
PROFESSIONAL ENGINEER

OF LOUIS AND THE STATE OF T

DE -- OPENING DEVICE SWITCH IN ACCESSIBLE

W Mane Street West Monroe,

LATEST REVISION: 11-12-2014

PROJ#

TYPICAL GUEST ROOMS ELECTRICAL PLANS

CHECKED BY: **□30**

10

13

4

15

16

SHEET NUMBER:

DRAWN BY: SWJ

DATE:

Richard Molenaar æ ဂ HITECT